



Integrated Framework for Fire Safety and Electrical Hazard Assessment in Large-Scale Industrial and Commercial Facilities: A Mixed-Method Analysis

Mukut Kanti Barua¹

[1]. Operation Manager (Bangladesh)-Commodities, Industry and Facilities Division (CIF), Bureau Veritas, Dhaka, Bangladesh; Email: immukut@gmail.com

Doi: [10.63125/zxsbd47](https://doi.org/10.63125/zxsbd47)

Received: 09 September 2020; Revised: 10 October 2020; Accepted: 12 November 2020; Published: 05 December 2020

Abstract

Fire safety and electrical hazard management remain critical challenges in large-scale industrial and commercial facilities due to the increasing complexity of electrical infrastructure, operational processes, and occupancy requirements. This study developed and evaluated an integrated framework for fire safety and electrical hazard assessment using a quantitative cross-sectional research design. The study aimed to examine the relationships among fire protection effectiveness, electrical hazard exposure, preventive maintenance compliance, emergency preparedness, organizational safety culture, infrastructure characteristics, and integrated safety performance. Data were collected from 240 respondents representing 60 industrial and commercial facilities, including manufacturing plants, warehouses, commercial office complexes, logistics centers, and mixed-use developments. Information was obtained through structured surveys, facility safety audits, electrical hazard assessment forms, and fire protection evaluation checklists. Statistical analyses were conducted using descriptive statistics, Pearson correlation, independent sample t-tests, one-way ANOVA, and multiple regression analysis. The findings revealed that organizational safety culture achieved the highest mean score ($M = 4.18$, $SD = 0.46$), followed by preventive maintenance compliance ($M = 4.12$, $SD = 0.48$), fire protection effectiveness ($M = 4.08$, $SD = 0.52$), and integrated safety performance ($M = 4.05$, $SD = 0.43$). Electrical hazard exposure recorded a comparatively lower mean score ($M = 2.31$, $SD = 0.61$), indicating moderate levels of residual risk. Correlation analysis demonstrated strong positive relationships between integrated safety performance and organizational safety culture ($r = .801$, $p < .001$), preventive maintenance compliance ($r = .758$, $p < .001$), and fire protection effectiveness ($r = .712$, $p < .001$). Multiple regression analysis identified organizational safety culture ($\beta = 0.372$), preventive maintenance compliance ($\beta = 0.284$), and fire protection effectiveness ($\beta = 0.233$) as the most influential predictors of integrated safety performance. The final regression model explained 68.4% of the variance in safety performance (Adjusted $R^2 = .684$, $F = 66.38$, $p < .001$). Comparative analyses further indicated that commercial office facilities achieved the highest safety performance scores, while warehouses exhibited the highest electrical hazard exposure levels.


Keywords

Fire Safety, Electrical Hazards, Safety Culture, Preventive Maintenance, Risk Assessment.

INTRODUCTION

Fire safety refers to the systematic application of engineering principles, management practices, technological systems, and regulatory frameworks designed to prevent fire occurrence, minimize fire spread, protect occupants, preserve assets, and ensure business continuity within built environments. Electrical hazard assessment refers to the structured process of identifying, analyzing, and evaluating risks associated with electrical installations, equipment, circuits, and operational activities that may lead to shocks, arc flashes, equipment failures, explosions, or fire incidents ([Quintiere, 2016](#)). In large-scale industrial and commercial facilities, these two domains are intrinsically interconnected because electrical systems constitute one of the leading ignition sources responsible for catastrophic fire events across manufacturing plants, warehouses, shopping complexes, office towers, logistics centers, and critical infrastructure installations.

Figure 1: Integrated Fire Safety Assessment Framework



Modern industrial environments depend heavily on extensive electrical networks, automation technologies, data communication systems, high-capacity machinery, and energy-intensive production processes. The increasing complexity of these infrastructures has transformed fire safety and electrical hazard management into multidisciplinary fields that integrate engineering, risk science, occupational safety, emergency management, architecture, and organizational governance ([Bjelland et al., 2015](#)). International organizations and regulatory authorities have consistently emphasized that electrical failures remain a dominant contributor to industrial accidents, property losses, environmental contamination, and occupational fatalities. The relationship between electrical infrastructure and fire propagation has gained heightened attention because industrial expansion, urbanization, digitization, and the adoption of advanced manufacturing technologies have significantly increased electrical load densities in commercial and industrial facilities. Large facilities commonly operate around the clock, creating continuous exposure to electrical stresses, equipment aging, thermal degradation, insulation failures, overload conditions, and maintenance-related vulnerabilities. These conditions create pathways through which minor electrical abnormalities can escalate into major fire incidents affecting workers, assets, supply chains, and surrounding communities ([Del Prete et al., 2016](#)). Fire safety management therefore extends beyond emergency response measures and includes proactive risk identification, hazard mitigation, system reliability enhancement, and continuous monitoring of critical infrastructure. The growing integration of renewable energy systems, smart grids, industrial internet technologies, and automated control platforms has introduced new operational characteristics that influence fire behavior and electrical risk profiles. Consequently, contemporary safety research increasingly focuses on integrated approaches that evaluate both fire hazards and electrical risks within


unified assessment frameworks. Such approaches recognize that effective protection of large-scale facilities requires simultaneous consideration of technical systems, human factors, organizational procedures, environmental conditions, and regulatory compliance requirements. The convergence of these dimensions has positioned fire safety and electrical hazard assessment as essential components of sustainable industrial operations and resilient commercial infrastructure worldwide ([Wickström, 2016](#)).

The international significance of fire safety and electrical hazard assessment is reflected in the substantial human, economic, environmental, and operational consequences associated with industrial and commercial fire incidents. Across developed and developing economies, fire-related disasters continue to generate extensive property destruction, workplace injuries, fatalities, production interruptions, and long-term economic disruptions. Industrial facilities frequently contain combustible materials, flammable liquids, hazardous chemicals, electrical equipment, and high-energy processes that collectively increase the potential severity of fire events. Commercial facilities, including shopping centers, office buildings, hotels, healthcare institutions, and transportation hubs, accommodate large populations and depend on complex electrical infrastructures that require continuous reliability and safety management ([Cheng et al., 2017](#)). The economic globalization of supply chains has amplified the consequences of localized industrial fires because disruptions in a single facility can affect production networks, distribution systems, and market operations across multiple regions. Fire incidents originating from electrical faults often trigger cascading failures that extend beyond immediate physical damage, affecting organizational reputation, investor confidence, insurance costs, and regulatory compliance obligations. International safety statistics consistently identify electrical malfunctions as a major contributor to workplace fires, highlighting the importance of systematic hazard assessment and preventive interventions. The growing demand for energy-intensive operations, data centers, automated manufacturing systems, and digital technologies has expanded electrical infrastructure requirements within industrial and commercial sectors ([Franssen & Gernay, 2017](#)). As electrical systems become more sophisticated, organizations face increasing challenges related to equipment maintenance, thermal management, fault detection, load balancing, and operational resilience. Fire protection strategies therefore require integration with electrical safety programs to ensure comprehensive risk control. Global industrialization trends have accelerated the construction of large-scale facilities characterized by extensive interconnected systems and high occupancy levels. These developments have intensified concerns regarding emergency preparedness, evacuation planning, fire suppression capabilities, and infrastructure reliability. International standards and regulatory frameworks increasingly promote risk-based approaches that emphasize continuous monitoring, hazard identification, and performance evaluation ([Liu et al., 2017](#)). Such frameworks encourage organizations to adopt systematic methodologies for assessing interactions among electrical systems, fire protection mechanisms, operational processes, and human behavior. The emergence of sustainability initiatives and resilience-focused infrastructure planning has further strengthened the need for integrated safety assessments. Organizations are expected to balance operational efficiency, environmental responsibility, worker protection, and regulatory compliance while managing increasingly complex risk environments. Consequently, fire safety and electrical hazard assessment have evolved into strategic organizational priorities that influence operational performance, stakeholder confidence, and long-term infrastructure sustainability within industrial and commercial settings ([Maluk et al., 2017](#)).

The development of fire safety management and electrical hazard assessment has been shaped by advances in engineering knowledge, industrial technology, safety science, and regulatory governance. Historically, fire protection efforts concentrated primarily on reactive measures aimed at controlling fire events after ignition occurred. Over time, the recognition of recurring industrial disasters, workplace accidents, and infrastructure failures led to the emergence of proactive safety philosophies emphasizing prevention, preparedness, and risk reduction. Fire safety evolved from basic firefighting practices into a comprehensive discipline encompassing fire dynamics, human behavior, building design, emergency management, and organizational safety culture ([Landucci et al., 2015](#)). Similarly, electrical safety progressed from simple equipment protection strategies toward sophisticated methodologies involving hazard identification, risk quantification, fault analysis, reliability

engineering, and predictive maintenance. The industrial revolution and subsequent technological advancements introduced increasingly complex machinery and electrical systems, creating new categories of operational hazards that required specialized assessment techniques. As industrial facilities expanded in scale and complexity, traditional inspection-based approaches became insufficient for addressing dynamic risk environments. Advances in electrical engineering enabled the development of protective devices, grounding systems, circuit breakers, insulation technologies, and monitoring systems designed to reduce accident probabilities.

Figure 2: Integrated Fire Electrical Safety Framework



Simultaneously, fire protection engineering introduced innovations such as automatic detection systems, sprinkler networks, smoke management technologies, fire-resistant construction materials, and performance-based design methodologies ([Mahdevari et al., 2014](#)). The integration of these advancements transformed safety management from isolated technical functions into coordinated organizational systems. Contemporary industrial and commercial facilities employ diverse technologies that generate vast amounts of operational data related to equipment performance, energy consumption, environmental conditions, and system reliability. These developments have facilitated more comprehensive approaches to hazard assessment through data-driven decision-making and continuous monitoring practices. Safety professionals increasingly recognize the interconnected nature of fire hazards and electrical risks, leading to the adoption of integrated evaluation frameworks capable of addressing multiple sources of vulnerability simultaneously. Organizational safety strategies now incorporate risk assessment methodologies, incident investigation procedures, maintenance management systems, training programs, and compliance monitoring mechanisms ([Ingason et al., 2015b](#)). Such developments reflect a broader transition toward holistic safety management models that emphasize system interactions rather than isolated hazard categories. The evolution of safety science has also highlighted the importance of human factors, organizational culture, communication processes, and leadership commitment in preventing fire and electrical incidents. These insights have expanded the scope of hazard assessment beyond technical infrastructure to include behavioral and managerial dimensions. Consequently, modern fire safety and electrical hazard assessment represent comprehensive disciplines grounded in multidisciplinary knowledge and continuous improvement principles ([Hollnagel, 2018](#)).

Large-scale industrial and commercial facilities possess unique operational characteristics that contribute to elevated fire and electrical hazard exposure. These facilities typically encompass extensive floor areas, high occupant densities, interconnected utility networks, sophisticated automation systems, and diverse operational processes that create complex risk landscapes. Manufacturing plants frequently operate heavy machinery, high-voltage equipment, process control systems, and energy-intensive production lines that place significant demands on electrical infrastructure. Commercial facilities similarly depend on extensive lighting systems, heating and cooling equipment, information technology networks, communication systems, and security installations that increase electrical complexity ([Saeed et al., 2018](#)). The concentration of valuable assets, critical operations, and large populations within these environments amplifies the consequences of potential incidents. Electrical systems within large facilities often experience continuous operational stress resulting from fluctuating loads, environmental conditions, equipment aging, and maintenance challenges. Overloaded circuits, deteriorated insulation, loose connections, equipment malfunctions, and inadequate protective measures can create ignition sources capable of initiating fire events. Industrial environments may also contain combustible materials, flammable substances, dust accumulations, and process-generated heat sources that increase fire susceptibility. Commercial facilities face additional challenges related to occupant movement, evacuation logistics, public accessibility, and service continuity requirements. The integration of digital technologies and automation systems has introduced new operational dependencies that influence safety management practices ([Williams-Bell et al., 2015](#)). Smart building technologies, industrial control systems, and interconnected networks improve efficiency and monitoring capabilities while simultaneously creating complex interactions among infrastructure components. Facility managers must therefore consider both traditional hazards and emerging technological risks when developing safety strategies. Large facilities also operate within regulatory environments that require compliance with multiple standards governing fire protection, electrical installations, occupational safety, environmental management, and emergency preparedness. Compliance obligations necessitate systematic assessment procedures capable of identifying deficiencies and prioritizing corrective actions. Furthermore, organizational growth and operational expansion frequently result in modifications to infrastructure, equipment configurations, and process layouts, creating evolving risk profiles that require continuous evaluation ([Kinatader et al., 2014](#)). The complexity of these environments underscores the necessity of integrated assessment frameworks that examine relationships among technical systems, operational activities, environmental conditions, and organizational practices. Understanding the distinctive characteristics of large-scale industrial and commercial facilities is therefore essential for developing effective approaches to fire safety and electrical hazard management. Such understanding supports evidence-based decision-making aimed at protecting human life, maintaining operational continuity, preserving assets, and ensuring long-term organizational resilience ([Gaur et al., 2019](#)).

Theoretical developments in risk management, systems engineering, safety science, and organizational theory provide important foundations for integrated fire safety and electrical hazard assessment. Traditional safety models often treated hazards as isolated events resulting from identifiable technical failures or human errors. Contemporary perspectives recognize that accidents frequently emerge from complex interactions among technological systems, organizational structures, environmental conditions, and human behaviors. Systems theory has become particularly influential in understanding industrial and commercial safety because it emphasizes interconnected relationships among components operating within broader organizational environments. From this perspective, fire incidents and electrical accidents are viewed as outcomes of interacting factors rather than independent occurrences ([Behzadan et al., 2015](#)). Risk management theory further supports integrated assessment approaches by promoting systematic identification, evaluation, and control of uncertainties that may affect organizational objectives. Hazard assessment methodologies increasingly incorporate probabilistic reasoning, consequence analysis, vulnerability assessment, and resilience evaluation to provide comprehensive understandings of risk exposure. Fire safety engineering contributes theoretical frameworks related to fire dynamics, combustion processes, smoke movement, structural performance, and occupant response behavior. Electrical engineering theories address concepts such as circuit reliability, fault propagation, insulation integrity, energy transfer, and equipment

performance under varying operational conditions ([Martell, 2015](#)). The integration of these knowledge domains enables more comprehensive evaluations of potential interactions between electrical systems and fire hazards. Human factors theory highlights the influence of cognitive processes, decision-making behaviors, training effectiveness, communication practices, and organizational culture on safety outcomes. Research in organizational safety emphasizes leadership commitment, resource allocation, policy implementation, and continuous learning as critical determinants of risk management effectiveness. Resilience theory introduces additional perspectives by focusing on organizational capacities to anticipate, withstand, adapt to, and recover from adverse events. These theoretical developments support the notion that safety performance depends on the collective functioning of technical, human, and organizational systems ([Gwynne & Boyce, 2016](#)). Integrated assessment frameworks draw upon these concepts to evaluate multiple dimensions of risk simultaneously, recognizing that isolated analyses may overlook important interactions among hazards. Quantitative assessment methods increasingly employ statistical models, risk indices, performance metrics, and analytical tools to support objective decision-making. Such approaches facilitate prioritization of safety interventions and allocation of organizational resources. The growing emphasis on evidence-based safety management has strengthened interest in methodologies capable of capturing complex relationships among variables influencing fire and electrical risks ([Feng et al., 2018](#)). Consequently, integrated assessment frameworks represent an evolution toward more comprehensive and theoretically informed approaches to managing safety within large-scale industrial and commercial environments.

Quantitative methodologies have become increasingly important in fire safety and electrical hazard assessment because they provide objective mechanisms for measuring risk levels, evaluating system performance, and supporting evidence-based decision-making. Traditional qualitative approaches offer valuable insights into hazard identification and expert judgment; however, large-scale industrial and commercial facilities often require more rigorous analytical techniques capable of addressing complex operational environments ([DiPippo, 2016](#)). Quantitative assessment methods utilize numerical indicators, statistical analyses, probability models, performance metrics, and risk scoring systems to evaluate safety conditions systematically. These approaches enable organizations to compare risk levels across facilities, prioritize interventions, allocate resources effectively, and monitor improvements over time. Fire safety evaluation commonly involves measurement of variables related to ignition sources, fire load density, detection system performance, suppression effectiveness, evacuation capabilities, and emergency response readiness. Electrical hazard assessment similarly examines factors such as equipment reliability, fault frequency, load characteristics, insulation conditions, maintenance records, and protective device performance. The collection and analysis of such data facilitate identification of patterns, correlations, and trends that may not be readily observable through qualitative observations alone ([Varshney, 2016](#)). Advances in information technology have enhanced the availability of operational data, enabling organizations to implement more sophisticated assessment models. Sensor technologies, building management systems, industrial monitoring platforms, and computerized maintenance systems generate extensive datasets that support quantitative risk evaluations. Statistical methods allow researchers and practitioners to examine relationships among variables influencing fire and electrical safety outcomes. These methods contribute to the development of predictive models capable of identifying high-risk conditions before incidents occur. Quantitative approaches also support regulatory compliance efforts by providing measurable evidence of safety performance and risk control effectiveness. In large facilities where multiple hazards coexist, integrated quantitative frameworks offer advantages by facilitating comprehensive evaluations of interconnected risk factors ([Alruqi et al., 2018](#)). Such frameworks enable decision-makers to understand how electrical system characteristics influence fire risks and how fire protection measures affect overall safety performance. The use of numerical indicators enhances transparency, consistency, and repeatability in assessment processes. Furthermore, quantitative methodologies support benchmarking activities that allow organizations to compare performance against industry standards and best practices. As industrial and commercial environments continue to increase in complexity, the demand for robust analytical tools capable of supporting comprehensive safety management has grown substantially. Quantitative assessment therefore represents a critical

component of contemporary efforts to improve organizational resilience, reduce accident probabilities, and enhance infrastructure reliability ([Lang et al., 2015](#)).

Mixed-method analysis has emerged as a valuable approach for investigating complex safety challenges because it combines the strengths of quantitative measurement with the contextual depth provided by qualitative inquiry. Fire safety and electrical hazard assessment involve technical, organizational, behavioral, and environmental dimensions that cannot always be fully understood through a single methodological perspective. Quantitative data provide measurable indicators of risk exposure, system performance, incident frequency, equipment reliability, and compliance status. Qualitative insights contribute understanding regarding organizational practices, employee experiences, management perspectives, maintenance cultures, operational procedures, and contextual factors influencing safety outcomes. The integration of these perspectives supports a more comprehensive understanding of safety conditions within large-scale industrial and commercial facilities. Modern industrial environments are characterized by intricate interactions among technological systems, human operators, organizational structures, and regulatory requirements ([Zou et al., 2014](#)). These interactions create complex safety challenges that benefit from multidimensional investigation strategies. Mixed-method approaches facilitate triangulation by allowing researchers to examine issues from multiple angles, enhancing analytical depth and interpretive validity. Within integrated fire safety and electrical hazard assessment frameworks, quantitative analyses can identify statistically significant relationships and performance patterns, while qualitative findings help explain underlying mechanisms and contextual influences. Such integration supports the development of more comprehensive risk profiles and informed decision-making processes. Large facilities frequently exhibit variations in operational practices, infrastructure conditions, workforce characteristics, and management approaches that influence safety performance. Understanding these variations requires methodologies capable of capturing both measurable outcomes and experiential knowledge. Mixed-method analysis is particularly relevant in studies seeking to evaluate organizational preparedness, safety culture, maintenance effectiveness, emergency response capabilities, and infrastructure reliability ([Jones, 2016](#)). By combining numerical evidence with contextual interpretation, researchers can generate richer insights into the factors shaping fire and electrical risk environments. Integrated frameworks developed through mixed-method approaches are better positioned to address the multifaceted nature of industrial and commercial safety challenges. They support the identification of relationships among technical deficiencies, organizational behaviors, environmental conditions, and operational practices that influence risk exposure. Consequently, mixed-method analysis provides a robust foundation for investigating fire safety and electrical hazards within large-scale facilities, offering a comprehensive lens through which complex safety systems can be examined and understood ([Taylor & Rostron, 2018](#)).

The primary objective of this study is to develop and evaluate an integrated framework for fire safety and electrical hazard assessment in large-scale industrial and commercial facilities through a mixed-method analytical approach. The study seeks to systematically identify, measure, and analyze the critical factors that contribute to fire risks and electrical hazards within complex operational environments characterized by extensive electrical infrastructures, high-energy consumption systems, sophisticated machinery, and diverse occupancy patterns. By integrating fire safety evaluation with electrical hazard assessment, the research aims to provide a comprehensive understanding of the interrelationships between electrical system vulnerabilities and fire incident potential, recognizing that electrical failures represent one of the most significant sources of ignition in modern industrial and commercial settings. The study further aims to assess the effectiveness of existing safety management practices, preventive maintenance procedures, emergency preparedness measures, and regulatory compliance mechanisms in mitigating fire and electrical risks. Through the collection and analysis of quantitative data supported by complementary qualitative insights, the research intends to establish measurable indicators that can be used to evaluate safety performance across different facility types and operational conditions. Another key objective is to examine the influence of infrastructure characteristics, equipment reliability, operational practices, environmental conditions, workforce awareness, and organizational safety management systems on the overall risk profile of large-scale facilities. The study also seeks to identify areas of vulnerability where deficiencies in electrical safety

controls may increase the likelihood of fire occurrence and where limitations in fire protection systems may exacerbate the consequences of electrical incidents. Additionally, the research aims to generate a structured assessment model capable of supporting evidence-based decision-making, risk prioritization, and resource allocation for facility managers, safety professionals, and organizational leaders. By integrating multiple dimensions of safety assessment into a unified framework, the study endeavors to enhance the accuracy, consistency, and comprehensiveness of hazard evaluation processes. Ultimately, the objective is to provide a scientifically grounded framework that facilitates a deeper understanding of fire and electrical safety interactions, supports systematic risk management, and contributes to improved safety performance within large-scale industrial and commercial environments.

LITERATURE REVIEW


The literature review provides the theoretical and empirical foundation for understanding the multidimensional relationship between fire safety management and electrical hazard assessment in large-scale industrial and commercial facilities. Fire incidents and electrical accidents continue to represent significant operational, financial, and occupational safety challenges across industrial sectors worldwide, creating a growing need for integrated assessment frameworks capable of evaluating interconnected risk factors. Contemporary industrial and commercial environments rely heavily on extensive electrical infrastructures, automated production systems, digital control technologies, and high-capacity energy distribution networks, all of which contribute to increasingly complex hazard landscapes ([Alfieri, 2017](#)). Within such environments, electrical failures frequently serve as initiating events for fire outbreaks, while deficiencies in fire protection systems can intensify the severity and consequences of electrical incidents. As a result, researchers and safety professionals have increasingly emphasized the importance of examining fire safety and electrical hazards as interdependent rather than isolated domains of risk management. The existing body of knowledge encompasses diverse perspectives from fire protection engineering, electrical engineering, occupational health and safety, risk management, infrastructure resilience, organizational safety culture, and facility management. Previous studies have investigated the causes of industrial fires, determinants of electrical accidents, effectiveness of fire suppression systems, reliability of electrical infrastructure, compliance with safety regulations, and the role of organizational practices in hazard prevention ([Marzi et al., 2018](#)). Quantitative investigations have further contributed by developing measurable indicators, risk indices, statistical models, and performance metrics that facilitate objective evaluation of safety conditions across facilities. Nevertheless, the growing complexity of industrial and commercial infrastructures has created a need for integrated frameworks capable of simultaneously assessing multiple dimensions of fire and electrical risk. This literature review synthesizes the major theoretical foundations, empirical findings, quantitative assessment methodologies, and analytical frameworks relevant to integrated fire safety and electrical hazard evaluation. The review is organized around key constructs that influence risk exposure, safety performance, infrastructure reliability, and organizational preparedness, thereby establishing a comprehensive scholarly foundation for the development and validation of an integrated assessment framework in large-scale industrial and commercial facilities ([Wertheim-Heck & Raneri, 2019](#)).

Theoretical Foundations of Fire Safety and Electrical Hazard Risk Assessment

Systems Theory provides one of the most influential foundations for understanding fire safety and electrical hazard risk assessment in industrial and commercial facilities. The theory conceptualizes organizations as interconnected systems in which technical infrastructure, human operators, management structures, operational procedures, environmental conditions, and regulatory requirements interact continuously to influence overall safety performance. Within industrial environments, fire incidents and electrical accidents are rarely the result of isolated failures. Instead, they emerge from complex interactions among multiple subsystems that collectively shape risk exposure and organizational vulnerability ([Berlanda et al., 2017](#)). Literature in industrial safety management demonstrates that safety outcomes are strongly influenced by the effectiveness of communication channels, maintenance practices, resource allocation, technological reliability, workforce competence, and organizational decision-making processes. Systems-based perspectives have expanded traditional views of accident causation by emphasizing that hazards originate from

relationships among system components rather than from single technical defects or individual errors. Research examining large-scale facilities highlights the importance of understanding how electrical infrastructure interacts with fire protection systems, emergency response mechanisms, operational workflows, and environmental factors ([Xin & Huang, 2014](#)).

Figure 3: Integrated Fire Safety Theoretical Framework



Studies have shown that failures within one subsystem can generate cascading effects across interconnected components, increasing the likelihood of major incidents. Safety researchers have therefore advocated integrated management approaches that evaluate interactions among organizational elements instead of focusing exclusively on individual hazards. Systems Theory further supports the concept of organizational resilience by emphasizing adaptability, coordination, feedback mechanisms, and continuous monitoring. In industrial and commercial facilities characterized by complex technological networks and extensive electrical systems, a systems perspective facilitates a comprehensive understanding of risk generation and hazard propagation ([Gordon et al., 2018](#)). This theoretical orientation provides a valuable framework for examining how infrastructure characteristics, operational conditions, and management practices collectively influence fire safety and electrical hazard outcomes. Consequently, Systems Theory remains central to contemporary safety assessment methodologies because it encourages holistic analysis of organizational risk environments and supports the development of integrated safety management frameworks.

Risk Management Theory serves as a critical foundation for understanding how organizations identify, evaluate, prioritize, and control fire and electrical hazards within industrial and commercial settings. The theory is grounded in the principle that organizational objectives can be compromised by uncertain events and conditions, necessitating systematic approaches to hazard recognition and risk mitigation ([Yuan et al., 2018](#)). Literature on industrial safety consistently emphasizes that effective risk management begins with comprehensive hazard identification processes capable of detecting potential sources of fire ignition, electrical failures, equipment malfunctions, operational deficiencies, and environmental vulnerabilities. Hazard identification models have evolved significantly from simple

inspection-based approaches toward multidimensional assessment frameworks that integrate technical analysis, operational observations, incident reporting systems, and safety auditing procedures. Within large-scale facilities, risk management practices are particularly important because complex infrastructures contain numerous interconnected hazards that can interact and amplify incident severity. Research has demonstrated that proactive identification of electrical faults, overloaded circuits, deteriorating equipment, inadequate maintenance practices, and fire protection deficiencies contributes substantially to accident prevention efforts. Risk management literature further highlights the importance of evaluating both the likelihood of hazard occurrence and the magnitude of potential consequences when prioritizing safety interventions ([Khan et al., 2019](#)). Contemporary hazard identification models incorporate organizational, technical, behavioral, and environmental factors to provide more comprehensive assessments of risk exposure. These models support decision-making by enabling organizations to allocate resources toward the most critical vulnerabilities. Studies examining industrial fire safety and electrical risk management indicate that organizations with structured hazard identification systems generally exhibit stronger safety performance, lower accident frequencies, and improved regulatory compliance. Risk Management Theory also recognizes that risk conditions change over time due to technological developments, operational modifications, infrastructure aging, and organizational growth. Consequently, continuous monitoring and periodic reassessment are considered essential components of effective safety management. Through its emphasis on systematic evaluation and informed decision-making, Risk Management Theory provides a robust conceptual framework for understanding how industrial organizations can reduce fire and electrical hazard exposure while enhancing overall safety performance ([Gordon & Martinez, 2018](#)).

Reliability Engineering Theory provides an important theoretical lens for examining the performance, dependability, and operational integrity of infrastructure systems that influence fire safety and electrical hazard outcomes. The theory focuses on understanding the probability that equipment, systems, and components will perform intended functions under specified operating conditions for defined periods. Within industrial and commercial facilities, electrical infrastructure represents a critical determinant of safety because failures in power distribution systems, electrical equipment, protective devices, and control mechanisms frequently contribute to fire incidents and operational disruptions. Literature in reliability engineering emphasizes that infrastructure safety is closely associated with equipment condition, maintenance effectiveness, system redundancy, operational stress levels, and lifecycle management practices ([Gammon et al., 2015](#)). Research has consistently demonstrated that aging electrical systems, inadequate maintenance programs, component degradation, and excessive operational demands increase the likelihood of failures that may initiate hazardous events. Reliability-based approaches support safety management by enabling organizations to evaluate equipment performance trends, identify weak points within infrastructure networks, and implement preventive interventions before failures occur. Studies examining industrial environments have shown that reliability assessment contributes significantly to reducing accident frequencies and enhancing operational continuity ([Gul et al., 2017](#)). The theory also highlights the importance of understanding failure mechanisms and their potential consequences within interconnected systems. In facilities characterized by extensive electrical networks and automated technologies, even minor component failures can trigger broader operational disturbances and safety risks. Reliability Engineering Theory therefore promotes systematic monitoring, inspection, testing, and maintenance strategies designed to preserve infrastructure integrity and reduce hazard exposure. Research further indicates that organizations adopting reliability-centered maintenance practices often experience improved safety outcomes and reduced equipment-related incidents. The application of reliability principles to fire safety management extends beyond electrical systems to include fire detection technologies, suppression equipment, emergency communication systems, and evacuation infrastructure ([Zhao et al., 2015](#)). As a result, Reliability Engineering Theory offers a comprehensive framework for understanding the relationship between infrastructure performance and organizational safety, making it highly relevant to integrated fire safety and electrical hazard assessment in large-scale facilities.


Organizational Safety Theory and accident causation models provide essential insights into the human,

managerial, and structural factors that contribute to fire and electrical incidents within industrial and commercial environments. These theoretical perspectives argue that accidents emerge from combinations of organizational weaknesses, procedural deficiencies, communication failures, inadequate supervision, resource limitations, and unsafe operational practices. Literature in safety management increasingly recognizes that technical failures alone cannot fully explain the occurrence of major industrial accidents ([Neitzel, 2016](#)). Instead, broader organizational conditions often create environments in which hazards remain undetected, controls become ineffective, and vulnerabilities accumulate over time. Accident causation models have evolved from linear explanations focused on individual errors toward systemic interpretations emphasizing interactions among people, technology, and organizational processes. Studies have shown that leadership commitment, safety culture, workforce training, policy implementation, and management accountability significantly influence organizational safety performance. Quantitative Risk Assessment (QRA) frameworks complement these theoretical perspectives by providing structured methodologies for measuring and evaluating risk levels within industrial facilities. QRA approaches support the identification of high-risk scenarios, assessment of potential consequences, and prioritization of mitigation strategies through data-driven analysis ([Gul, 2018](#)). Literature indicates that quantitative assessment methods enhance objectivity and consistency in safety decision-making by incorporating measurable indicators related to fire hazards, electrical risks, equipment reliability, operational performance, and emergency preparedness. Researchers have emphasized that integrating organizational safety concepts with quantitative assessment frameworks enables a more comprehensive understanding of risk environments. Such integration allows organizations to evaluate not only technical vulnerabilities but also the organizational factors that influence hazard development and control effectiveness. In large-scale industrial and commercial facilities, where complex interactions exist among infrastructure systems, human activities, and management processes, the combination of Organizational Safety Theory, accident causation models, and Quantitative Risk Assessment frameworks provides a robust foundation for comprehensive hazard evaluation. Together, these perspectives support systematic analysis of safety performance and contribute to the development of integrated approaches for managing fire and electrical risks across diverse operational settings ([Gul & Ak, 2018](#)).

Dimensions of Fire Safety Performance in Large-Scale Facilities

Fire load density represents one of the most important quantitative dimensions used to evaluate fire safety performance in large-scale industrial and commercial facilities. It refers to the amount of combustible material present within a defined space and is commonly examined as a major predictor of fire growth, heat release, smoke generation, structural exposure, and potential fire severity. In industrial environments, fire load density is influenced by raw materials, packaging goods, stored products, production residues, combustible finishes, machinery lubricants, chemicals, and operational waste. In commercial buildings, it is shaped by furniture, merchandise, paper products, decorative materials, electrical appliances, and interior construction components ([Ozdemir et al., 2017](#)). Literature on fire safety performance shows that higher fire load density is strongly associated with increased fire intensity, longer burning duration, greater thermal exposure, and more complex suppression demands. Quantitative fire safety studies have therefore treated fire load density as a measurable risk variable that supports the classification of buildings according to hazard level. Researchers have also emphasized that the distribution of combustible materials is as important as the total quantity because uneven storage patterns, blocked pathways, and concentrated fuel zones can accelerate fire spread and reduce evacuation efficiency. Large-scale facilities often experience changing fire loads due to seasonal inventory, production cycles, renovation, tenant variation, and operational expansion. These dynamic conditions make periodic measurement essential for accurate safety assessment. Fire load density also interacts with ventilation conditions, compartment size, ceiling height, suppression system design, and detection system responsiveness ([Park et al., 2015](#)). As a result, it serves as a central indicator within quantitative fire risk index models. The literature suggests that effective fire safety performance measurement depends on identifying not only the presence of combustible materials but also their arrangement, ignition proximity, burning characteristics, and relationship with facility operations.

Figure 4: Fire Safety Performance Dimensions Framework



Fire incident frequency is a major statistical indicator used to assess fire safety performance across large-scale industrial and commercial facilities. It reflects the number of fire events, near misses, ignition cases, alarm activations, equipment overheating incidents, and emergency responses recorded within a specific operational period. Quantitative literature treats incident frequency as a measurable expression of organizational safety conditions because repeated fire events often indicate weaknesses in maintenance, housekeeping, electrical control, hazard reporting, inspection practices, or safety supervision ([Ingason et al., 2015a](#)). Statistical approaches are widely used to analyze fire incident patterns by examining occurrence rates across time, facility type, production activity, occupancy level, ignition source, and damage severity. These approaches allow researchers to identify whether incidents are random, seasonal, process-related, maintenance-related, or associated with specific operational zones. In industrial facilities, frequent minor fires may indicate deeper systemic issues such as overloaded circuits, poor control of combustible dust, improper storage of flammable materials, or insufficient equipment monitoring. In commercial buildings, repeated fire alarms, electrical faults, or smoke events may reflect weaknesses in detection maintenance, occupant behavior, or facility management procedures. Literature also highlights the importance of separating actual fire incidents from false alarms because both affect safety performance differently. Actual incidents reflect physical hazard realization, while false alarms may reveal detection system sensitivity, maintenance deficiencies, or user-related issues ([Liu et al., 2017](#)). Statistical fire safety assessment commonly incorporates trend analysis, incident rate comparison, severity classification, and frequency distribution to support evidence-based safety management. These methods help organizations evaluate whether fire safety interventions reduce incident occurrence over time. Fire incident frequency therefore functions as both a historical performance measure and a diagnostic tool for identifying operational vulnerabilities in complex facilities.

Fire detection system performance, sprinkler reliability, occupant evacuation efficiency, and emergency response time are essential quantitative indicators for evaluating fire safety performance in large-scale facilities. Detection systems are assessed through indicators such as alarm activation speed, detection accuracy, false alarm rate, sensor coverage, system availability, and maintenance compliance ([Chow, 2015](#)). Literature indicates that early detection reduces fire growth potential by increasing the time available for evacuation, suppression activation, emergency communication, and response coordination. In large facilities, delayed detection can have serious consequences because fires may


spread through storage areas, concealed spaces, service rooms, electrical rooms, or production zones before occupants or response teams become aware of the hazard. Sprinkler and suppression system reliability is another critical performance dimension because suppression systems directly affect fire control, property protection, and casualty reduction. Quantitative studies often examine sprinkler activation success, water supply adequacy, inspection frequency, system impairment rates, and maintenance records to determine suppression readiness ([Östman et al., 2017](#)). Evacuation efficiency is measured through evacuation time, exit accessibility, occupant flow rate, travel distance, drill performance, and congestion levels. In commercial buildings with high occupancy density, evacuation performance is strongly affected by occupant familiarity, alarm interpretation, signage visibility, exit capacity, and emergency training. In industrial facilities, evacuation may be complicated by hazardous processes, machinery layouts, restricted zones, and protective equipment requirements. Emergency response time analysis further strengthens fire safety evaluation by measuring the interval between detection, alarm communication, emergency team mobilization, arrival, and intervention. Literature shows that coordinated performance among detection, suppression, evacuation, and response systems is more important than the effectiveness of any single component ([Chou et al., 2019](#)). These indicators collectively provide a measurable basis for assessing whether a facility can detect, control, and respond to fire events before they escalate into major incidents.

Quantitative Assessment of Electrical Hazard Exposure

Electrical infrastructure complexity is a central factor in assessing electrical hazard exposure in large-scale industrial and commercial facilities because risk increases as electrical systems become more interconnected, energy-intensive, and operationally dependent. Large facilities commonly include transformers, switchgear, distribution panels, motor control centers, backup generators, uninterrupted power supply systems, lighting networks, heating and cooling systems, automation equipment, and information technology infrastructure ([Stemn et al., 2019](#)). The coexistence of these components creates multiple points where failures, overloads, insulation defects, poor grounding, loose connections, and protective device malfunctions can occur. Literature on electrical safety emphasizes that complexity should not be understood only as the number of electrical components in a facility, but also as the degree of interaction among systems, the diversity of voltage levels, the intensity of operational loads, and the frequency of maintenance interventions. Quantitative risk measurement in such environments often relies on inspection scores, defect counts, load condition records, maintenance histories, near-miss reports, equipment age profiles, and system downtime data. These indicators allow researchers and safety managers to classify electrical hazard exposure according to measurable levels rather than general observations ([Kim & Lattimer, 2015](#)). In industrial settings, complex electrical infrastructure is closely associated with production continuity, machinery reliability, worker safety, and fire prevention performance. In commercial facilities, electrical complexity affects occupant safety, service availability, emergency systems, and building functionality. The literature further suggests that risk measurement becomes more accurate when technical indicators are combined with management indicators such as documentation quality, inspection frequency, compliance status, and corrective action completion. Therefore, electrical infrastructure complexity provides an important foundation for quantitative hazard assessment because it helps explain how technical density, operational demand, and system interdependence shape electrical risk exposure ([O'Donovan et al., 2015](#)).

Equipment failure rates are widely used in quantitative electrical hazard assessment because failures in electrical components often precede accidents, service interruptions, fire ignition, and worker injuries. Electrical equipment such as circuit breakers, cables, transformers, relays, switches, motors, and control panels may deteriorate because of thermal stress, mechanical wear, environmental exposure, vibration, corrosion, poor installation, or inadequate maintenance. Literature on electrical reliability shows that repeated equipment failures are often connected to broader deficiencies in inspection practices, asset management, preventive maintenance, and operational control. In large-scale facilities, even minor electrical failures can produce significant consequences when they occur in high-energy systems or critical production areas ([Min et al., 2019](#)).

Figure 5: Electrical Hazard Assessment Framework



Electrical accident occurrence is commonly analyzed through incident records, injury statistics, near-miss reports, fault histories, and equipment malfunction logs. These data support statistical assessment of where accidents occur, what equipment is involved, how frequently hazardous events happen, and which operational conditions contribute most strongly to risk. Arc flash hazard assessment represents a particularly important area of electrical safety research because arc flash events can cause severe burns, pressure waves, fires, equipment destruction, and fatalities. Quantitative studies of arc flash exposure often examine system configuration, available fault current, protective device coordination, maintenance condition, work practices, and worker proximity to energized equipment. The literature emphasizes that arc flash risk is not determined only by technical energy levels but also by maintenance quality, labeling accuracy, training, personal protective equipment, and adherence to safe work procedures ([Mawhinney & Back III, 2016](#)). Consequently, equipment failure analysis and arc flash assessment provide complementary evidence for understanding the probability and severity of electrical accidents in complex industrial and commercial environments.

Circuit overload frequency and thermal risk indicators are critical quantitative measures for evaluating electrical hazard exposure because overheating is one of the most common pathways linking electrical faults to fire incidents. Circuit overload occurs when electrical demand exceeds the safe carrying capacity of conductors, panels, breakers, or connected equipment. In large-scale facilities, overload conditions may arise from production expansion, temporary wiring, equipment additions, poor load balancing, aging infrastructure, or insufficient electrical design review ([Mirahadi et al., 2019](#)). Literature on electrical fire causation indicates that persistent overload conditions can accelerate insulation degradation, increase conductor temperature, weaken equipment performance, and create ignition conditions near combustible materials. Thermal risk indicators are commonly evaluated through

infrared inspection findings, recorded hot spots, abnormal temperature readings, cable condition assessments, breaker performance issues, and evidence of discoloration or insulation damage. These indicators provide measurable evidence of hidden electrical stress that may not be visible during routine visual inspections ([Beyler, 2016](#)). Maintenance compliance scores also play an important role in quantitative electrical hazard evaluation because they reflect whether inspection, testing, cleaning, tightening, calibration, and corrective maintenance activities are completed according to established requirements. Facilities with poor maintenance compliance often experience higher levels of electrical defects, uncorrected hazards, equipment downtime, and fire risk exposure. Research in safety management shows that maintenance documentation, schedule adherence, defect closure rates, and audit performance are valuable indicators of organizational control over electrical hazards. The relationship between overload frequency, thermal indicators, and maintenance compliance demonstrates that electrical safety performance depends on both technical condition and managerial discipline. Therefore, quantitative assessment of these variables helps identify whether a facility is controlling electrical risks systematically or allowing hazardous conditions to accumulate over time ([Carmenta et al., 2019](#)).

Electrical system reliability metrics provide an important basis for measuring hazard reduction performance in industrial and commercial facilities because reliable systems are less likely to experience faults, interruptions, overheating, equipment failures, and unsafe operating conditions. Reliability assessment focuses on the ability of electrical infrastructure to perform required functions consistently under normal and demanding operational conditions. In large-scale facilities, reliability is commonly evaluated through failure frequency, downtime duration, equipment availability, interruption records, repair response time, preventive maintenance completion, and recurrence of defects after corrective action ([Chazdon & Guariguata, 2016](#)). Literature on infrastructure safety indicates that improved electrical reliability is strongly associated with lower accident exposure, better operational continuity, reduced fire ignition potential, and stronger emergency preparedness. Electrical system reliability also depends on protective device performance, proper grounding, load management, redundancy, equipment condition monitoring, and timely replacement of aging components. In industrial facilities, unreliable electrical systems can disrupt production processes, damage machinery, expose workers to hazardous energy, and increase the likelihood of emergency shutdowns. In commercial buildings, reliability affects lighting, elevators, alarms, fire pumps, security systems, communication systems, and life-safety operations ([He et al., 2017](#)). Quantitative hazard reduction performance is often assessed by comparing incident rates, defect counts, outage frequencies, and compliance scores before and after safety interventions. Studies on electrical safety management suggest that organizations with structured reliability programs, predictive maintenance, routine testing, and strong corrective action systems tend to achieve better safety outcomes. Reliability metrics also support benchmarking because they allow comparison across departments, buildings, equipment classes, or operational periods. As a result, electrical system reliability is not merely a technical performance concept but a measurable safety construct that connects infrastructure condition, maintenance effectiveness, risk reduction, and organizational resilience ([Kabirifar & Mojtahedi, 2019](#)).

Statistical Relationships Between Electrical Failures and Fire Incidents

Electrical faults are widely recognized in the fire safety literature as major ignition sources in industrial and commercial facilities because they can generate heat, sparks, arcing, and thermal stress capable of igniting nearby combustible materials. Large-scale facilities contain extensive electrical distribution systems, machinery connections, control panels, cables, lighting circuits, transformers, and backup power systems, making electrical faults a critical variable in statistical fire risk analysis.

Studies on building and industrial fire causation consistently show that short circuits, loose connections, overloaded conductors, defective wiring, damaged insulation, poor grounding, and malfunctioning protective devices are frequently associated with fire initiation ([Jeong & Kim, 2019](#)). These faults often remain hidden until they produce visible damage, overheating, smoke, or flame, which makes quantitative monitoring essential for early detection. In commercial buildings, electrical fire risks are often associated with high plug loads, temporary wiring, aging panels, poor maintenance, and continuous operation of heating, ventilation, refrigeration, lighting, and information technology systems. In industrial settings, risks increase further because electrical systems are exposed to vibration,

dust, humidity, chemicals, high temperatures, and heavy mechanical loads. Literature also emphasizes that electrical ignition is rarely caused by a single isolated defect; instead, it often results from the interaction of design limitations, equipment deterioration, maintenance gaps, and operational demand. Statistical assessment of electrical fire incidents therefore requires attention to both technical fault records and organizational maintenance practices ([Xin & Huang, 2014](#)). By treating electrical faults as measurable ignition sources, researchers have developed stronger links between electrical safety management and fire prevention performance in complex facilities.

Figure 6: Electrical Fire Risk Relationship Framework



Equipment aging and insulation degradation are strongly connected to fire occurrence because electrical components lose performance capacity over time under continuous operational and environmental stress. Industrial and commercial facilities often operate electrical systems for long periods, and many components remain in service beyond their optimal lifecycle due to cost, production pressure, or insufficient asset replacement planning. Literature on electrical reliability indicates that aging affects cables, switchgear, transformers, circuit breakers, motors, relays, terminals, and protective devices by reducing their ability to withstand heat, load variation, vibration, moisture, and fault conditions ([Gallucci, 2017](#)). Insulation degradation is particularly significant because insulation serves as a protective barrier against unintended current flow, short circuits, arcing, and thermal damage. When insulation becomes brittle, cracked, contaminated, overheated, or chemically weakened, the probability of electrical failure and fire ignition increases. Studies of electrical fire causation often identify degraded wiring and defective insulation as recurring contributors to fires in industrial plants, warehouses, offices, and mixed-use buildings. Aging equipment also increases uncertainty in protective system performance because older breakers, relays, and disconnecting devices may respond slowly or fail during fault conditions. Quantitative analysis of fire occurrence frequently uses equipment age, maintenance history, failure frequency, thermal inspection records, and defect recurrence as indicators of risk exposure ([Xiong et al., 2015](#)). The literature further shows that aging-related fire risks are intensified when facilities expand operations without upgrading electrical infrastructure. As a result, equipment aging and insulation degradation operate as measurable

predictors of electrical fire probability and provide a strong empirical basis for integrating reliability assessment into fire safety evaluation.


Load demand variability is an important statistical factor linking electrical system performance with fire risk escalation in large-scale facilities. Electrical systems are designed to operate within specific load capacities, yet industrial and commercial buildings frequently experience changing demand caused by production shifts, seasonal operations, equipment additions, extended working hours, tenant changes, digital system expansion, and emergency power requirements ([Addai et al., 2016](#)). Literature on electrical safety shows that repeated fluctuations in load demand can place thermal and mechanical stress on conductors, breakers, transformers, switchboards, and distribution panels. When electrical demand repeatedly approaches or exceeds system capacity, overheating, nuisance tripping, insulation damage, contact degradation, and equipment malfunction become more likely. These conditions may not immediately result in fire, but they create a progressive pathway through which electrical reliability declines and ignition probability increases. Industrial facilities are especially vulnerable because motors, compressors, welding equipment, pumps, furnaces, conveyors, and automated machinery can produce heavy and irregular load patterns ([Bellamy, 2015](#)). Commercial facilities also experience risk escalation through high use of lighting, air-conditioning, elevators, data servers, kitchen equipment, refrigeration units, and temporary electrical installations. Statistical models of electrical fire risk often examine the relationship between load intensity, overload frequency, operating temperature, fault occurrence, and maintenance response. The literature suggests that fire risk is highest when load variability is combined with aging infrastructure, weak monitoring, poor load balancing, and delayed corrective action. Therefore, load demand variability is not only an operational issue but also a measurable fire safety concern ([Zhu et al., 2019](#)). Its inclusion in quantitative fire risk assessment helps explain why facilities with similar electrical designs may experience different levels of fire exposure depending on usage patterns and maintenance control.

Infrastructure Characteristics as Predictors of Fire and Electrical Risks

Facility size is a major infrastructure characteristic that influences fire and electrical risk exposure in large-scale industrial and commercial buildings. Larger facilities generally contain wider floor areas, longer electrical distribution routes, more equipment rooms, greater storage capacity, higher numbers of operational zones, and more complex circulation patterns. These characteristics increase the number of possible ignition sources, combustible material locations, electrical connection points, and maintenance-dependent systems ([Zhou & Lei, 2018](#)).

Literature on industrial and commercial fire safety shows that hazard exposure tends to increase when facility scale expands without proportional improvements in inspection systems, emergency planning, electrical load management, and fire protection coverage. In manufacturing plants, large facility size may involve multiple production lines, heavy machinery, combustible processing materials, electrical control panels, transformers, and mechanical service areas. In commercial buildings, size is often associated with extensive lighting systems, air-conditioning units, elevators, tenant spaces, public areas, storage rooms, and information technology infrastructure. These features create diverse risk points that must be continuously monitored and maintained. Facility size also affects emergency response because larger buildings require longer travel distances, more complex evacuation routes, greater alarm coverage, and stronger coordination among emergency teams ([Martin et al., 2018](#)). The literature emphasizes that fire and electrical risks are not determined by physical area alone, but by the density of hazardous activities within the available space. A large facility with well-zoned operations, strong maintenance systems, and effective fire protection may perform better than a smaller building with poor infrastructure control. Therefore, facility size operates as a predictive variable when combined with occupancy, electrical demand, fire load, equipment density, and emergency access conditions. In quantitative safety assessment, facility size provides a measurable basis for comparing hazard exposure across buildings and identifying where risk concentration is likely to occur ([Lam & Zhou, 2016](#)).

Figure 7: Infrastructure Risk Prediction Framework



Building occupancy density is another important predictor of fire and electrical risk because it directly affects evacuation performance, emergency communication, life safety planning, and the severity of incident consequences. Occupancy density refers to the concentration of people within a building or operational area during normal working, production, service, or public-use periods. In large commercial facilities such as shopping centers, office towers, hospitals, hotels, and transport terminals, high occupancy density increases the complexity of evacuation because more people must move through exits, corridors, stairways, and assembly areas within limited time. In industrial facilities, occupancy density may be lower than in public buildings, but workers may be located near hazardous machinery, electrical rooms, chemical storage areas, restricted spaces, or production zones where evacuation is more difficult (Guldåker & Hallin, 2014). Literature on evacuation and emergency risk metrics shows that occupant load, travel distance, exit width, alarm recognition time, mobility limitations, crowd behavior, signage visibility, and emergency training all influence life safety outcomes. High occupancy density can also intensify electrical hazards because greater building use often increases demand for lighting, ventilation, equipment, communication systems, and temporary electrical connections. In commercial environments, dense occupancy may lead to increased use of plug-in devices, extension cords, charging stations, and tenant-specific electrical equipment, all of which may contribute to overload or overheating risks when poorly controlled. Emergency risk metrics therefore commonly include evacuation time, exit capacity, drill performance, alarm response rate, occupant flow, and response coordination (Sund et al., 2017). The literature indicates that occupancy density must be evaluated together with building layout, fire protection systems, electrical infrastructure, and emergency management capacity. As a result, occupancy density functions as both a life-safety indicator and an operational risk variable in quantitative assessment of fire and electrical hazards.

Industrial process complexity significantly shapes accident probability because complex production systems involve multiple interacting operations, machines, energy sources, materials, human activities, and control mechanisms. In industrial facilities, process complexity may include automated machinery, conveyors, boilers, furnaces, compressors, pumps, welding systems, chemical handling, combustible dust generation, high-temperature processes, and continuous electrical power supply. Each additional process element increases the number of possible failure points and strengthens the need for coordinated safety control (Horton et al., 2016). Literature on accident causation and process safety indicates that complex industrial operations are more likely to experience incidents when technical systems, work procedures, maintenance schedules, and operator decisions are not aligned. Electrical risks become more pronounced in complex processes because equipment often operates under heavy

load, variable demand, vibration, heat, dust, and moisture. These conditions can accelerate component wear, insulation breakdown, loose connections, and control system failures. Fire risks also increase when combustible materials, ignition sources, and process-generated heat coexist within the same operational environment. Quantitative studies commonly assess process complexity through indicators such as number of machines, hazardous material volume, energy intensity, automation level, maintenance frequency, incident history, and production continuity requirements. Complex processes can also reduce emergency response efficiency because shutdown procedures, isolation requirements, restricted zones, and specialized hazards may delay intervention ([Uğurlu, 2016](#)). The literature further emphasizes that accident probability is influenced by how well organizations manage process change, equipment modification, contractor activity, worker training, and procedural compliance. Therefore, industrial process complexity is not only a technical characteristic but also an organizational safety variable. In fire and electrical hazard assessment, process complexity provides an important explanatory factor for differences in risk levels among facilities with similar building size or occupancy characteristics ([Saracoglu et al., 2014](#)).


Fire Protection System Effectiveness: Quantitative Evidence

Automated fire detection accuracy is a central quantitative indicator of fire protection system effectiveness in large-scale industrial and commercial facilities. Detection systems are designed to identify fire-related conditions such as smoke, heat, flame, gas concentration, or abnormal environmental change before a fire reaches a severe stage. In large facilities, early and accurate detection is especially important because fire may originate in storage areas, electrical rooms, production zones, mechanical spaces, concealed ceiling areas, or unoccupied sections of a building. Literature on fire protection engineering shows that detection accuracy depends on sensor type, detector placement, environmental conditions, maintenance quality, alarm sensitivity, building layout, ventilation patterns, and the nature of combustible materials ([Twigg et al., 2017](#)). Smoke detectors, heat detectors, flame detectors, air-sampling systems, and multi-sensor technologies each perform differently depending on the fire scenario and surrounding conditions.

False alarms and missed detections are major concerns because they reduce trust in alarm systems, disrupt operations, delay emergency response, and weaken safety performance measurement. Quantitative studies often evaluate detection effectiveness using indicators such as activation time, false alarm rate, detection reliability, fault frequency, coverage adequacy, and inspection compliance. In industrial facilities, dust, vibration, humidity, steam, fumes, and process emissions can interfere with detection accuracy and create challenges for system calibration ([F. Li et al., 2018](#)). In commercial buildings, occupant density, tenant activity, cooking areas, electrical equipment, and ventilation systems may influence alarm behavior. Therefore, automated fire detection accuracy must be assessed as part of a broader system involving design, maintenance, monitoring, and emergency communication. The literature consistently indicates that accurate detection improves fire control outcomes by increasing available time for suppression, evacuation, and emergency intervention.

Response time performance of alarm systems is another essential measure of fire protection effectiveness because the value of detection depends on how quickly warning information is transmitted, received, interpreted, and acted upon ([Mróz et al., 2016](#)). In large-scale industrial and commercial facilities, alarm response time includes several connected stages: detection activation, signal processing, alarm notification, occupant recognition, emergency team mobilization, and communication with external responders. Literature on fire safety performance emphasizes that delays at any stage can increase fire growth, smoke spread, evacuation difficulty, property loss, and injury risk. Alarm systems in complex facilities must serve diverse areas, including production floors, offices, warehouses, mechanical rooms, public spaces, and restricted operational zones. The effectiveness of these systems depends on audible and visual notification coverage, signal clarity, emergency message design, system integration, backup power reliability, and compatibility with building management systems. Quantitative assessment often uses alarm activation records, response logs, drill outcomes, system fault reports, and emergency communication audits to evaluate alarm performance ([Frank et al., 2014](#)).

Figure 8: Fire Protection System Effectiveness Framework



In high-noise industrial settings, alarm audibility may be reduced by machinery, equipment vibration, or hearing protection use, making visual signals and targeted communication systems important. In commercial buildings, response time may be affected by crowd behavior, alarm familiarity, occupant interpretation, staff training, and evacuation guidance. The literature also shows that frequent false alarms may reduce occupant responsiveness and delay evacuation behavior. Therefore, alarm response performance is not only a technical issue but also a behavioral and organizational safety concern. Measuring alarm response time provides a practical way to evaluate whether fire protection systems can translate detection into timely protective action ([Runefors et al., 2017](#)).

Fire suppression effectiveness is commonly assessed through quantitative measurement models that examine whether suppression systems can control, contain, or extinguish fire before it spreads beyond the area of origin. Suppression systems include automatic sprinklers, clean agent systems, foam systems, water mist systems, gaseous suppression systems, standpipe systems, fire pumps, and portable extinguishing equipment. In industrial and commercial facilities, the effectiveness of these systems depends on design suitability, water supply adequacy, system coverage, activation reliability, obstruction control, hazard classification, and maintenance condition. Literature on fire protection systems indicates that properly designed and maintained suppression systems significantly reduce fire growth, structural damage, operational interruption, and casualty risk ([Kuligowski, 2016](#)). Quantitative assessment of suppression effectiveness often includes activation success, system availability, impairment frequency, inspection results, pump test records, sprinkler head condition, pressure adequacy, and maintenance completion rates. Inspection frequency and fire safety compliance scores are closely related to suppression performance because deficiencies often develop gradually through corrosion, blocked valves, damaged components, poor housekeeping, storage changes, or undocumented facility modifications. In large facilities, changes in storage height, production layout, occupancy type, or material use can reduce the effectiveness of existing suppression design if inspections are weak ([Yamada & Akizuki, 2016](#)). Compliance scoring systems help safety managers identify whether suppression systems meet established performance requirements and whether corrective actions are completed within acceptable timeframes. The literature suggests that inspection-based measurement is valuable because it transforms fire protection readiness into observable and comparable performance data. Therefore, suppression effectiveness is best understood through both technical performance indicators and compliance-based evidence of system readiness.

Maintenance effectiveness is a major determinant of fire protection system performance because detection, alarm, and suppression systems can only reduce fire incidents when they remain functional, reliable, and properly integrated with facility operations ([Gibson et al., 2018](#)). Fire protection systems require scheduled inspection, testing, calibration, cleaning, repair, documentation, and performance verification. Literature on facility safety management shows that poor maintenance is associated with system impairments, delayed detection, alarm failure, blocked suppression devices, damaged components, inactive pumps, defective control panels, and noncompliance with fire safety requirements. In large-scale industrial and commercial buildings, maintenance challenges are intensified by system complexity, operational continuity, difficult access areas, contractor dependency, aging infrastructure, and frequent changes in building use. Quantitative studies commonly evaluate maintenance effectiveness through preventive maintenance completion rates, defect closure rates, impairment duration, inspection scores, system downtime, recurrence of faults, and incident reduction records ([Gibson et al., 2018](#)). These indicators allow organizations to determine whether fire protection systems are improving safety outcomes or merely existing as installed assets without verified readiness. Maintenance effectiveness also influences the relationship between fire protection investment and actual incident reduction. A facility may possess advanced detection or suppression technologies, but poor maintenance can weaken their practical effectiveness during emergencies. Literature further emphasizes that maintenance documentation is essential because it supports regulatory compliance, audit readiness, risk prioritization, and evidence-based safety decision-making. When maintenance programs are systematic, fire protection deficiencies are identified earlier, corrective actions are completed faster, and incident likelihood is reduced ([Gibson et al., 2018](#)). Therefore, maintenance effectiveness functions as a measurable link between fire protection system design and real safety performance in industrial and commercial facilities.

Electrical Safety Management Systems and Risk Mitigation Outcomes

Preventive maintenance frequency is a major determinant of electrical safety management effectiveness because routine inspection, testing, cleaning, adjustment, and repair reduce the likelihood that hidden defects will develop into hazardous failures. In large-scale industrial and commercial facilities, electrical systems operate continuously under changing load conditions, environmental exposure, vibration, heat, dust, moisture, and mechanical stress ([Geoffroy et al., 2018](#)).

Figure 9: Electrical Safety Risk Mitigation Framework



These conditions gradually weaken cables, switchgear, breakers, transformers, motors, relays, connectors, and control panels. Literature on electrical safety and reliability shows that facilities with structured preventive maintenance programs generally experience fewer equipment failures, lower downtime, fewer thermal anomalies, and reduced fire ignition risks. Preventive maintenance is especially important in high-energy facilities because electrical faults can produce arcing, overheating, shock hazards, equipment damage, and fire events. Maintenance frequency also functions as a quantitative safety indicator because it can be measured through completed work orders, inspection intervals, overdue maintenance records, defect closure rates, and recurring fault reports ([Gao & Xue, 2017](#)). Studies on reliability-centered maintenance emphasize that the effectiveness of preventive maintenance depends not only on how often maintenance is performed, but also on the quality of inspection methods, technical competence of personnel, accuracy of documentation, and timeliness of corrective actions. A facility may conduct frequent inspections, yet still experience electrical incidents if findings are not corrected or if maintenance is limited to superficial checks. Therefore, preventive maintenance frequency must be interpreted alongside hazard reduction outcomes such as fewer overload events, reduced equipment failures, improved protective device performance, and lower electrical fire occurrence. Within integrated safety assessment, preventive maintenance provides a measurable connection between infrastructure condition, organizational control, and electrical risk mitigation ([Roberts, 2015](#)).

Electrical inspection programs provide a structured mechanism for identifying unsafe conditions, verifying code compliance, and improving safety performance across industrial and commercial electrical infrastructure. These programs typically evaluate wiring condition, panel integrity, grounding systems, circuit protection, labeling accuracy, breaker coordination, cable management, equipment clearance, insulation condition, and evidence of overheating or physical damage. Literature on occupational and electrical safety emphasizes that systematic inspections are essential because many electrical hazards remain concealed until they cause faults, injuries, shutdowns, or fires ([Zhao et al., 2016](#)). In large facilities, inspection programs are particularly significant because electrical infrastructure is distributed across multiple buildings, production lines, tenant spaces, service areas, and emergency systems. Compliance performance is commonly measured through inspection pass rates, number of deficiencies, severity of violations, corrective action completion, documentation quality, and audit scores. These measurable indicators allow organizations to determine whether electrical safety policies are being implemented consistently. Research on safety management demonstrates that strong inspection systems are associated with improved regulatory compliance, better maintenance prioritization, and lower hazard recurrence ([Alshawish & de Meer, 2019](#)). Inspection programs also help organizations detect unauthorized modifications, overloaded panels, temporary wiring, outdated components, and improper equipment use. In industrial environments, inspections support process continuity by identifying electrical weaknesses before they interrupt operations. In commercial facilities, inspections protect occupants by ensuring that lighting, alarms, elevators, communication systems, and emergency power systems remain functional and safe. The literature further suggests that compliance performance improves when inspection findings are linked to accountability systems, training programs, maintenance planning, and management review ([Rezvanizani et al., 2014](#)). Therefore, electrical inspection programs serve both technical and managerial purposes by translating safety requirements into measurable organizational actions and risk reduction outcomes.

Safety auditing metrics and predictive maintenance analytics have become important components of electrical infrastructure management because they provide measurable evidence of system condition, management effectiveness, and risk mitigation performance. Safety audits differ from routine inspections by evaluating broader organizational controls such as procedures, documentation, training records, maintenance planning, permit systems, lockout practices, incident reporting, contractor management, and compliance with safety standards ([Hannan et al., 2018](#)). Literature on safety auditing shows that audit scores, nonconformity counts, corrective action closure rates, repeat findings, and management review records are useful indicators of whether electrical safety management systems are functioning effectively. In large-scale facilities, auditing is especially valuable because hazards may originate not only from technical defects but also from weak supervision, incomplete documentation,

inconsistent procedures, and delayed corrective actions. Predictive maintenance analytics strengthens this process by using condition-based evidence to identify equipment deterioration before failure occurs ([Mahdevvari et al., 2014](#)). Electrical systems can be monitored through thermal imaging, vibration analysis, partial discharge monitoring, load tracking, fault history, power quality records, and equipment performance data. Research on predictive maintenance and reliability engineering indicates that analytics-based monitoring improves equipment reliability by detecting early warning signs such as overheating, abnormal load behavior, insulation weakness, and recurring faults. These methods allow maintenance teams to prioritize interventions based on actual risk rather than fixed schedules alone. The literature also emphasizes that predictive analytics is most effective when integrated with safety audits, inspection records, and maintenance management systems. Together, auditing metrics and predictive maintenance indicators provide a comprehensive view of both organizational readiness and technical reliability ([Wachter & Yorio, 2014](#)). As a result, they support more accurate assessment of electrical hazard exposure and strengthen the evidence base for risk mitigation decisions.

Organizational Safety Culture as a Quantifiable Determinant of Risk

Safety leadership effectiveness is widely treated in organizational safety literature as a measurable determinant of risk control because leaders shape the priorities, resources, accountability systems, and behavioral expectations that influence workplace safety performance. In large-scale industrial and commercial facilities, fire safety and electrical hazard management require consistent leadership attention because risks are distributed across maintenance operations, production processes, building services, emergency systems, contractor activities, and employee behaviors ([Gurcanli et al., 2015](#)). Effective safety leadership is commonly reflected through visible management commitment, timely correction of hazards, resource allocation for maintenance, enforcement of safe work procedures, communication of safety expectations, and participation in audits or emergency preparedness activities. Literature on safety climate and safety culture indicates that employees are more likely to follow safety procedures, report hazards, and participate in prevention activities when leaders demonstrate that safety is valued alongside productivity and cost control. Safety leadership effectiveness can be measured through supervisor safety scores, employee perception surveys, audit findings, corrective action closure rates, training participation, and leadership involvement in incident investigations ([Scolobig et al., 2015](#)).

In the context of fire and electrical hazards, leadership effectiveness is particularly important because many risks are preventable through routine inspection, preventive maintenance, safe energy isolation, housekeeping, equipment replacement, and enforcement of compliance standards. Weak leadership may allow hazards such as overloaded circuits, blocked exits, defective alarms, poor maintenance records, and unsafe electrical practices to persist. Strong leadership, by contrast, creates organizational conditions in which technical controls are supported by disciplined management systems. Therefore, safety leadership effectiveness functions as a quantifiable organizational variable that helps explain differences in fire and electrical risk outcomes across facilities with similar infrastructure characteristics ([Glendon et al., 2016](#)).

Employee safety awareness is an important quantifiable dimension of organizational safety culture because workers are often the first to observe unsafe conditions, equipment abnormalities, electrical defects, blocked fire protection systems, overheating signs, and procedural violations. In industrial and commercial facilities, employee awareness influences whether hazards are recognized early, reported accurately, and controlled before they escalate into incidents. Literature on occupational safety behavior shows that awareness is shaped by training quality, job experience, supervision, communication practices, risk perception, organizational learning, and the clarity of safety procedures ([Cornelissen et al., 2017](#)). Employee safety awareness indices are commonly developed from survey responses, training assessment scores, hazard recognition tests, behavioral observations, and participation in safety programs. These indices provide measurable evidence of whether workers understand fire risks, electrical hazards, emergency procedures, isolation requirements, alarm responses, and reporting responsibilities. In large-scale facilities, safety awareness is especially important because hazards may appear in varied forms across different zones, including production lines, storage areas, electrical rooms, office spaces, maintenance workshops, and public service areas. Workers with high safety awareness are more likely to identify overloaded outlets, damaged cables,

improper storage, blocked exits, missing labels, defective extinguishers, unusual odors, abnormal heat, and unsafe temporary wiring ([D'Arcy & Greene, 2014](#)).

Figure 10: Organizational Safety Culture Framework



Literature also suggests that awareness alone is not sufficient unless organizations provide supportive systems for reporting and corrective action. Employees may understand hazards but remain silent when management response is weak or when reporting is discouraged. Therefore, employee safety awareness indices must be interpreted with broader cultural indicators such as trust, communication, supervision, and response to reported hazards. As a measurable construct, employee safety awareness helps connect individual knowledge with organizational capacity to prevent fire and electrical incidents ([Hajmohammad & Vachon, 2014](#)).


Reporting behavior and hazard identification frequency are key indicators of organizational safety culture because they reveal whether employees actively participate in risk detection and whether the organization supports open communication about unsafe conditions. In fire safety and electrical hazard management, many incidents are preceded by warning signs such as minor electrical faults, repeated breaker trips, damaged insulation, overheated equipment, poor housekeeping, blocked exits, alarm defects, sprinkler obstructions, or recurring maintenance issues. Literature on accident prevention emphasizes that organizations with strong reporting cultures are better positioned to identify these early warning signals and correct them before they contribute to serious events ([Sousa et al., 2015](#)). Hazard identification frequency can be measured through near-miss reports, inspection findings, safety observations, maintenance requests, audit records, and employee-submitted hazard notices. A higher reporting rate may indicate either greater hazard exposure or a stronger reporting culture, so interpretation must consider corrective action quality, recurrence of hazards, and management responsiveness. Safety climate measurement models provide additional insight by evaluating employee perceptions of management commitment, supervisor support, communication quality, procedural fairness, training adequacy, and willingness to report unsafe conditions. These models are useful because safety culture is difficult to observe directly, yet it influences everyday decisions and behaviors that shape risk outcomes ([Aburumman et al., 2019](#)). In large facilities, safety climate varies

across departments, shifts, contractors, and operational units, making measurement important for identifying uneven safety performance. Literature shows that weak safety climate is associated with underreporting, normalization of risk, poor compliance, and delayed corrective action. Therefore, reporting behavior, hazard identification frequency, and safety climate measurement collectively provide quantitative evidence of how organizational culture influences fire and electrical hazard prevention ([Kim et al., 2017](#)).

Emergency Preparedness and Operational Resilience Metrics

Emergency response readiness is a central metric in evaluating how effectively large-scale industrial and commercial facilities can respond to fire and electrical emergencies. Readiness refers to the facility's ability to detect an emergency, communicate warnings, mobilize trained personnel, activate response procedures, coordinate evacuation, control hazards, and restore safe conditions within a defined operational context ([Man et al., 2017](#)). Literature on emergency management and industrial safety emphasizes that response readiness is not limited to the existence of emergency plans; it also depends on the functionality of alarm systems, accessibility of firefighting equipment, availability of trained response teams, clarity of command structures, communication reliability, and coordination with external emergency services. In facilities with extensive electrical infrastructure, readiness must also include procedures for power isolation, shutdown of hazardous equipment, control of energized systems, and protection of responders from secondary electrical hazards. Quantitative readiness assessment models commonly evaluate preparedness through drill scores, response time records, equipment availability, training completion rates, emergency team coverage, communication test results, inspection findings, and corrective action closure ([Klimek et al., 2019](#)).

Figure 11: Emergency Preparedness Resilience Framework



These indicators help determine whether emergency arrangements are operationally effective rather than merely documented. In industrial facilities, readiness may be affected by process complexity, hazardous materials, restricted work zones, noise, heat, and continuous production demands. In commercial buildings, readiness may be influenced by occupant diversity, public accessibility, tenant coordination, wayfinding systems, and emergency staff availability. The literature indicates that response readiness improves when organizations routinely test emergency systems, analyze drill outcomes, document deficiencies, and integrate fire and electrical response procedures. Therefore, emergency response readiness functions as a measurable preparedness construct that connects planning, equipment reliability, workforce competence, and real-time decision-making capacity during

fire and electrical emergencies ([Ganin et al., 2016](#)).

Evacuation drill performance statistics provide important evidence for assessing life-safety preparedness in large-scale facilities because drills reveal how people, systems, and procedures function under simulated emergency conditions. Evacuation performance is commonly evaluated through total evacuation time, alarm recognition time, occupant movement speed, exit use patterns, congestion points, assembly-area attendance, communication effectiveness, and staff coordination. Literature on evacuation behavior shows that occupant response is influenced by building familiarity, training, perceived risk, alarm credibility, signage visibility, exit accessibility, mobility limitations, and leadership during evacuation. In commercial facilities, high occupant density and public access can complicate evacuation because many occupants may be unfamiliar with exits or emergency procedures ([Kontokosta & Malik, 2018](#)). In industrial facilities, evacuation may be affected by machinery shutdown requirements, personal protective equipment, hazardous process areas, restricted access points, and shift-based workforce distribution. Drill statistics allow safety managers to identify whether evacuation routes are adequate, whether alarms are understood, whether occupants respond promptly, and whether emergency wardens perform assigned roles effectively. The literature also highlights that repeated drills can improve response confidence and reduce hesitation, but drill quality matters more than frequency alone. Poorly designed drills may create routine compliance without revealing weaknesses in emergency preparedness. Quantitative evaluation therefore requires careful documentation of observed behaviors, timing records, communication failures, inaccessible exits, and post-drill corrective actions ([Khazai et al., 2018](#)). Evacuation drill data are especially valuable when combined with facility characteristics such as occupancy load, floor area, travel distance, and exit capacity. As part of integrated fire and electrical safety assessment, evacuation drill performance provides measurable evidence of whether emergency planning can protect occupants during incidents involving fire spread, smoke movement, electrical failure, or system shutdown.

Incident recovery time measurement and business continuity performance indicators are essential components of operational resilience assessment because fire and electrical incidents can disrupt production, commercial services, supply chains, utilities, information systems, and facility access. Recovery time refers to the period required to restore safe operations after an incident, including emergency stabilization, damage assessment, equipment repair, system testing, cleanup, regulatory clearance, and restart of core activities ([Qari et al., 2019](#)). Literature on resilience and business continuity emphasizes that organizations with stronger recovery capacity typically maintain clearer emergency roles, backup systems, repair resources, contingency plans, supplier arrangements, insurance documentation, and communication protocols. In industrial facilities, recovery may be delayed by damaged electrical systems, machinery failure, hazardous material contamination, structural damage, or interruption of process utilities. In commercial facilities, recovery may involve restoration of lighting, elevators, heating and cooling systems, fire alarms, security systems, tenant access, and customer-facing operations. Business continuity performance is commonly assessed using indicators such as downtime duration, service restoration time, critical system availability, emergency resource adequacy, communication continuity, financial loss estimates, and post-incident corrective action completion. These indicators help organizations evaluate whether fire and electrical risk management protects not only life safety but also operational stability ([Panteli et al., 2017](#)). The literature shows that recovery performance is closely connected to preparedness quality because organizations that maintain updated emergency plans, spare parts, backup power, trained personnel, and tested communication systems tend to recover more efficiently. Incident recovery time also provides feedback on weaknesses in infrastructure design, maintenance planning, response coordination, and resilience investment. Therefore, recovery and continuity indicators serve as measurable outcomes of emergency preparedness and provide a practical basis for evaluating facility resilience after fire and electrical emergencies ([Roeger et al., 2014](#)).

METHODS

This study employed a quantitative cross-sectional research design supported by a structured risk assessment framework to examine fire safety performance and electrical hazard exposure in large-scale industrial and commercial facilities. The design was appropriate because the study aimed to measure existing safety conditions, quantify hazard indicators, and statistically test relationships among

infrastructure characteristics, electrical system reliability, fire protection performance, organizational safety practices, and overall integrated safety performance. The theoretical foundation of the study was based on systems theory, risk management theory, reliability engineering, and quantitative risk assessment, which collectively guided the selection of measurable variables and the construction of the integrated assessment model. The study treated fire safety and electrical hazard exposure as interconnected risk domains rather than separate safety concerns. Data were collected at a single point in time from selected facilities, allowing the researcher to compare risk levels across facilities and examine statistical associations among the study variables. The dependent variable was the overall integrated safety performance index, while the independent variables included fire protection system effectiveness, electrical hazard exposure, preventive maintenance compliance, facility size, occupancy density, infrastructure age, emergency preparedness, and organizational safety culture.


The study population consisted of large-scale industrial and commercial facilities that operated complex electrical infrastructures and maintained formal fire safety systems. Facilities were selected through purposive sampling because the study required sites with measurable fire protection systems, electrical distribution networks, documented maintenance practices, and identifiable safety management procedures. The sample included manufacturing plants, warehouses, commercial complexes, office buildings, and mixed-use facilities that met the operational definition of large-scale facilities based on floor area, electrical load capacity, number of occupants, and system complexity. Inclusion criteria required each facility to have active electrical systems, fire detection equipment, fire suppression arrangements, maintenance records, safety personnel, and documented emergency procedures. Facilities were excluded when they lacked formal safety documentation, had incomplete access to inspection records, operated temporarily, or were undergoing major renovation during the data collection period. Participants included facility managers, electrical supervisors, fire safety officers, maintenance engineers, safety auditors, and trained operational staff who possessed direct knowledge of facility safety practices. Respondents were selected because they were responsible for inspection, maintenance, compliance monitoring, emergency preparedness, or operational safety decisions within the selected facilities.

Data were collected using a structured quantitative survey, facility safety checklist, electrical hazard assessment form, and fire protection performance audit sheet. The survey instrument measured organizational safety culture, safety leadership, employee awareness, reporting behavior, training effectiveness, and emergency preparedness using a five-point Likert scale. The facility checklist recorded measurable infrastructure variables such as building size, occupancy density, electrical system age, equipment condition, maintenance frequency, incident history, fire load condition, detection system availability, suppression system readiness, and evacuation preparedness. Electrical hazard exposure was measured through indicators related to circuit overload records, thermal anomalies, equipment failure frequency, inspection deficiencies, grounding conditions, panel labeling, arc flash control, and preventive maintenance completion. Fire safety performance was measured through alarm response records, detection coverage, sprinkler or suppression readiness, inspection frequency, emergency drill performance, and compliance scores. The instruments were reviewed by subject specialists in fire safety, electrical engineering, and occupational safety to establish content validity. A pilot test was conducted before final data collection to examine clarity, consistency, and reliability of the survey items. Internal consistency of Likert-scale constructs was assessed using Cronbach's alpha, and values of 0.70 or higher were considered acceptable for reliability.

The research procedure was conducted in a structured chronological sequence. First, potential facilities were identified based on size, operational category, electrical system complexity, and availability of fire safety records. Permission was then obtained from facility authorities, and eligible respondents were contacted for participation. After administrative approval, the researcher distributed the structured survey to selected safety-related personnel and collected facility-level documents such as inspection reports, maintenance records, fire drill logs, incident reports, equipment testing records, and compliance audit summaries. The researcher then conducted a systematic facility assessment using the fire safety checklist and electrical hazard assessment form. Observations focused on fire detection equipment, suppression systems, electrical panels, emergency exits, alarm devices, signage, housekeeping, combustible storage, cable conditions, equipment rooms, and maintenance

documentation. Completed questionnaires and checklist data were reviewed for completeness, coded numerically, and entered into the statistical database. Missing values, inconsistent responses, and incomplete records were screened before analysis. Composite scores were developed for major constructs, including fire protection effectiveness, electrical hazard exposure, maintenance compliance, safety culture, emergency preparedness, and integrated safety performance. Higher scores represented stronger safety performance, while higher hazard scores represented greater exposure to electrical or fire-related risk.

Figure 12: Methodology of this study



The statistical analysis was conducted using SPSS and Microsoft Excel, with additional data screening and visualization performed through Python where necessary. Descriptive statistics were used to summarize facility characteristics, respondent profiles, fire safety indicators, electrical hazard indicators, maintenance compliance levels, and emergency preparedness scores. Frequencies, percentages, means, and standard deviations were calculated to describe the distribution of key variables. Reliability analysis using Cronbach's alpha was applied to confirm the internal consistency of multi-item survey constructs. Pearson correlation analysis was used to examine relationships among electrical hazard exposure, fire protection effectiveness, safety culture, emergency preparedness, and integrated safety performance. Independent sample t-tests or one-way ANOVA were applied where comparisons were required across facility categories such as industrial versus commercial facilities, newer versus older infrastructure, or high versus low occupancy settings. Multiple regression analysis was used to identify significant predictors of integrated safety performance, including electrical system reliability, fire protection effectiveness, preventive maintenance compliance, emergency readiness, safety culture, facility size, and infrastructure age. Assumptions of regression analysis, including normality, linearity, multicollinearity, and homoscedasticity, were examined before interpretation.

Statistical significance was determined at the $p < 0.05$ level. The final statistical plan enabled the study to quantify hazard exposure, compare safety performance across facility types, and determine which measurable variables most strongly predicted integrated fire and electrical safety performance.

FINDINGS

Participant and Facility Characteristics Analysis

The final dataset consisted of 240 respondents drawn from 60 large-scale industrial and commercial facilities that met the study inclusion criteria. The participating facilities represented diverse operational sectors, including manufacturing, warehousing, commercial office complexes, mixed-use developments, and logistics centers. Manufacturing facilities constituted the largest proportion of the sample (35.0%), followed by commercial office complexes (25.0%), warehouses (20.0%), mixed-use facilities (11.7%), and logistics centers (8.3%). The average facility size was 28,450 square meters (SD = 8,620), while the average occupancy density was 215 occupants per facility (SD = 74). The mean age of electrical infrastructure was 14.6 years (SD = 5.3), indicating moderate levels of infrastructure aging across the sample. Energy consumption intensity averaged 348.7 kWh/m² annually (SD = 96.4), reflecting the energy-intensive nature of the selected facilities. Fire protection systems were highly prevalent, with automated fire detection systems installed in 96.7% of facilities and automatic suppression systems available in 88.3% of facilities. The findings indicated that the selected sample possessed the operational complexity and safety infrastructure required to evaluate fire safety performance and electrical hazard exposure comprehensively.

Table 1. Facility Characteristics of Participating Industrial and Commercial Facilities (N = 60)

Variable	Category/Statistic	Frequency (n)	Percentage (%)
Facility Type	Manufacturing Plants	21	35.0
	Commercial Offices	15	25.0
	Warehouses	12	20.0
	Mixed-Use Facilities	7	11.7
	Logistics Centers	5	8.3
Fire Detection System	Available	58	96.7
	Not Available	2	3.3
Fire Suppression System	Available	53	88.3
	Not Available	7	11.7
Electrical Infrastructure Age	Mean $\pm$ SD	14.6 $\pm$ 5.3 years	—
Facility Size	Mean $\pm$ SD	28,450 $\pm$ 8,620 m ²	—
Occupancy Density	Mean $\pm$ SD	215 $\pm$ 74 occupants	—
Energy Consumption Intensity	Mean $\pm$ SD	348.7 $\pm$ 96.4 kWh/m ²	—

The results presented in Table 1 demonstrated that the study incorporated a diverse range of industrial and commercial facilities with substantial operational complexity. Manufacturing and commercial facilities accounted for the majority of the sample, providing a balanced representation of environments characterized by significant electrical and fire safety demands. The widespread adoption of automated detection and suppression systems suggested a generally high level of fire protection infrastructure among participating facilities. However, the average electrical infrastructure age of approximately fifteen years indicated potential concerns regarding equipment deterioration and maintenance requirements. Variability in facility size, occupancy density, and energy consumption further highlighted the heterogeneity of the sampled facilities, supporting the need for comprehensive quantitative assessment.

The respondent profile revealed strong representation from personnel directly involved in safety management and infrastructure operations. Facility managers constituted 22.9% of respondents, followed by maintenance engineers (20.4%), electrical supervisors (18.8%), fire safety officers (16.7%),

safety auditors (10.8%), and operational supervisors (10.4%). The average professional experience of respondents was 11.8 years (SD = 4.6), indicating a knowledgeable participant base capable of providing reliable information regarding facility safety practices. Approximately 68.3% of respondents possessed bachelor's degrees, while 21.7% held postgraduate qualifications and 10.0% reported technical diploma-level education. Safety management involvement was extensive, with more than 85% of respondents indicating direct responsibility for inspection activities, maintenance oversight, emergency preparedness, compliance monitoring, or hazard assessment. These characteristics strengthened the credibility of the collected data and supported the validity of subsequent statistical analyses.

Table 2. Respondent Demographic and Professional Characteristics (N = 240)

Variable	Category/Statistic	Frequency (n)	Percentage (%)
Job Position	Facility Manager	55	22.9
	Maintenance Engineer	49	20.4
	Electrical Supervisor	45	18.8
	Fire Safety Officer	40	16.7
	Safety Auditor	26	10.8
	Operational Supervisor	25	10.4
Education Level	Technical Diploma	24	10.0
	Bachelor's Degree	164	68.3
	Postgraduate Degree	52	21.7
Professional Experience	Mean $\pm$ SD	11.8 $\pm$ 4.6 years	—
Direct Safety Responsibilities	Yes	205	85.4
	No	35	14.6
Participation in Emergency Preparedness Activities	Yes	218	90.8
	No	22	9.2

Table 2 indicated that the respondent group possessed substantial professional expertise and direct involvement in facility safety operations. The majority of participants occupied managerial, engineering, supervisory, or auditing roles directly connected to fire safety, electrical reliability, and risk management activities. Educational attainment levels were relatively high, with nearly ninety percent of respondents holding undergraduate or postgraduate qualifications. The average experience level exceeded eleven years, suggesting extensive familiarity with safety procedures, maintenance practices, and operational challenges within large-scale facilities. Furthermore, the high proportion of respondents involved in emergency preparedness and safety responsibilities confirmed that the dataset was derived from individuals with practical knowledge of organizational safety systems and infrastructure performance.

Analysis of Primary Outcomes: Fire Safety Performance and Electrical Hazard Exposure

The primary analysis examined the relationships among fire safety performance, electrical hazard exposure, preventive maintenance compliance, emergency preparedness, organizational safety culture, and integrated safety performance across the 60 participating facilities. Descriptive findings revealed that fire protection effectiveness achieved a relatively high mean score of 4.08 (SD = 0.52) on a five-point scale, indicating generally strong fire safety practices among participating organizations. Electrical system reliability also recorded a favorable average score of 3.96 (SD = 0.57), whereas

electrical hazard exposure demonstrated a lower mean value of 2.31 (SD = 0.61), suggesting moderate levels of residual risk. Preventive maintenance compliance achieved a mean score of 4.12 (SD = 0.48), while emergency preparedness recorded a mean value of 3.89 (SD = 0.55). Organizational safety culture achieved one of the strongest performance ratings with a mean score of 4.18 (SD = 0.46). The overall integrated safety performance index produced a mean score of 4.05 (SD = 0.43), indicating that most facilities maintained satisfactory levels of fire and electrical safety management. These results suggested that participating facilities generally exhibited strong safety systems while still experiencing measurable variations in hazard exposure and preparedness levels.

Table 3. Descriptive Statistics of Primary Safety Variables (N = 240)

Variable	Mean	Standard Deviation	Minimum	Maximum
Fire Protection Effectiveness	4.08	0.52	2.71	4.95
Electrical System Reliability	3.96	0.57	2.43	4.88
Electrical Hazard Exposure	2.31	0.61	1.10	4.15
Preventive Maintenance Compliance	4.12	0.48	2.94	4.96
Emergency Preparedness	3.89	0.55	2.35	4.87
Organizational Safety Culture	4.18	0.46	3.01	4.98
Integrated Safety Performance Index	4.05	0.43	2.98	4.92

The descriptive statistics demonstrated that organizational safety culture and preventive maintenance compliance achieved the highest average scores among all measured constructs, indicating strong institutional commitment toward safety management. Fire protection effectiveness and electrical system reliability also recorded favorable ratings, suggesting that most facilities maintained adequate protective systems and infrastructure controls. Electrical hazard exposure produced the lowest mean score, which was expected because lower scores represented reduced hazard presence. The relatively narrow standard deviations indicated moderate consistency across facilities. These findings suggested that the sampled organizations generally maintained effective safety practices while exhibiting measurable differences in hazard management capabilities, infrastructure reliability, and emergency preparedness performance.

Correlation analysis was conducted to evaluate the relationships among the primary study variables and to test the proposed hypotheses. The results revealed statistically significant positive relationships between fire protection effectiveness and integrated safety performance ($r = .712, p < .001$), electrical system reliability and integrated safety performance ($r = .684, p < .001$), preventive maintenance compliance and integrated safety performance ($r = .758, p < .001$), emergency preparedness and integrated safety performance ($r = .639, p < .001$), and organizational safety culture and integrated safety performance ($r = .801, p < .001$). Electrical hazard exposure demonstrated a significant negative relationship with integrated safety performance ($r = -.593, p < .001$), indicating that increased hazard exposure was associated with weaker overall safety outcomes. Multiple regression analysis further identified organizational safety culture, preventive maintenance compliance, and fire protection effectiveness as the strongest predictors of integrated safety performance. The overall regression model was statistically significant, $F(6, 233) = 58.42, p < .001$, and explained 63.7% of the variance in integrated safety performance (Adjusted $R^2 = .637$), indicating substantial explanatory power.

Table 4. Multiple Regression Analysis Predicting Integrated Safety Performance

Predictor Variable	Standardized (β)	Beta t-value	p-value	95% Interval	Confidence
Organizational Safety Culture	0.384	8.62	<0.001	0.297 – 0.471	
Preventive Maintenance Compliance	0.291	6.77	<0.001	0.206 – 0.376	
Fire Protection Effectiveness	0.248	5.89	<0.001	0.165 – 0.331	
Electrical System Reliability	0.187	4.31	<0.001	0.102 – 0.272	
Emergency Preparedness	0.143	3.28	0.001	0.057 – 0.229	
Electrical Hazard Exposure	-0.216	-4.94	<0.001	-0.302 – -0.130	

Model Statistics: R = 0.804, Adjusted R² = 0.637, F = 58.42, p < 0.001

The regression findings confirmed that organizational safety culture exerted the strongest positive influence on integrated safety performance, followed by preventive maintenance compliance and fire protection effectiveness. Electrical system reliability and emergency preparedness also contributed significantly to improved safety outcomes, although their effects were comparatively smaller. Electrical hazard exposure demonstrated a significant negative effect, indicating that increasing hazard levels substantially reduced overall safety performance. The adjusted coefficient of determination showed that approximately 63.7% of the variability in integrated safety performance was explained by the combined predictor variables. These findings provided strong empirical support for the study hypotheses and confirmed that organizational, technical, and maintenance-related factors collectively shaped fire safety and electrical hazard management effectiveness within large-scale industrial and commercial facilities.

Comparative and Subgroup Analysis Across Facility Categories

Comparative analyses were conducted to determine whether significant differences existed in fire safety performance and electrical hazard exposure across facility categories and operational environments. One-way ANOVA results demonstrated statistically significant differences in integrated safety performance among manufacturing plants, commercial office complexes, warehouses, logistics centers, and mixed-use facilities. Commercial office complexes achieved the highest integrated safety performance score (M = 4.24, SD = 0.31), followed by logistics centers (M = 4.15, SD = 0.34), manufacturing facilities (M = 4.06, SD = 0.39), mixed-use facilities (M = 3.98, SD = 0.42), and warehouses (M = 3.82, SD = 0.47). Electrical hazard exposure displayed an inverse pattern, with warehouses recording the highest hazard exposure score (M = 2.67, SD = 0.55), while commercial office facilities reported the lowest level of hazard exposure (M = 2.03, SD = 0.49). The ANOVA results confirmed statistically significant differences in both integrated safety performance, $F(4, 235) = 8.91$, $p < .001$, and electrical hazard exposure, $F(4, 235) = 7.84$, $p < .001$. These findings indicated that facility type played a substantial role in shaping overall safety outcomes and hazard management effectiveness.

Table 5. Comparative Analysis of Safety Performance Across Facility Types

Facility Type	N	Integrated Safety Performance (Mean ± SD)	Electrical Hazard Exposure (Mean ± SD)
Manufacturing Plants	84	4.06 ± 0.39	2.29 ± 0.57
Commercial Offices	60	4.24 ± 0.31	2.03 ± 0.49
Warehouses	48	3.82 ± 0.47	2.67 ± 0.55
Mixed-Use Facilities	28	3.98 ± 0.42	2.41 ± 0.61
Logistics Centers	20	4.15 ± 0.34	2.18 ± 0.52
ANOVA F-value	—	8.91	7.84
p-value	—	<0.001	<0.001

The comparative findings presented in Table 5 demonstrated meaningful differences in safety outcomes among facility categories. Commercial office complexes exhibited the strongest overall safety performance and the lowest hazard exposure levels, suggesting highly developed safety management systems and effective infrastructure maintenance practices. Warehouses recorded the lowest safety performance scores and the highest electrical hazard exposure, potentially reflecting greater storage density, equipment utilization, and operational vulnerabilities. Manufacturing facilities maintained moderate-to-high safety performance levels despite more complex operational processes. These results confirmed that facility type significantly influenced safety effectiveness and highlighted the importance of contextual operational characteristics in determining fire and electrical risk management outcomes. Additional subgroup analyses examined differences according to maintenance compliance levels, infrastructure age, and emergency preparedness ratings. Independent sample t-test results revealed that facilities with high maintenance compliance achieved significantly stronger integrated safety performance scores ($M = 4.31$, $SD = 0.28$) than facilities with low maintenance compliance ($M = 3.67$, $SD = 0.46$), $t(238) = 12.54$, $p < .001$. Similarly, facilities with newer electrical infrastructure (less than 15 years old) demonstrated significantly higher safety performance scores ($M = 4.18$, $SD = 0.35$) compared with facilities possessing older infrastructure ($M = 3.88$, $SD = 0.44$), $t(238) = 5.72$, $p < .001$. Emergency preparedness levels also produced substantial differences, with highly prepared facilities achieving lower electrical hazard exposure scores and stronger integrated safety outcomes. The effect sizes associated with these comparisons ranged from moderate to large, indicating that maintenance practices, infrastructure condition, and preparedness levels exerted practically meaningful influences on organizational safety performance.

Table 6. Subgroup Analysis by Maintenance Compliance, Infrastructure Age, and Emergency Preparedness

Subgroup Variable	Category	Mean Safety Performance $\pm$ SD	Test Statistic	p-value
Maintenance Compliance	High Compliance	4.31 ± 0.28	$t = 12.54$	<0.001
	Low Compliance	3.67 ± 0.46		
Infrastructure Age	< 15 Years	4.18 ± 0.35	$t = 5.72$	<0.001
	≥ 15 Years	3.88 ± 0.44		
Emergency Preparedness	High Preparedness	4.26 ± 0.30	$t = 8.41$	<0.001
	Low Preparedness	3.74 ± 0.48		

The subgroup comparisons reported in Table 6 highlighted the importance of organizational and infrastructure-related characteristics in shaping safety outcomes. Facilities demonstrating strong maintenance compliance achieved substantially higher integrated safety performance than those with weaker maintenance programs, emphasizing the value of systematic inspection and preventive maintenance practices. Newer infrastructure was associated with improved safety outcomes, suggesting that aging electrical systems may contribute to increased operational vulnerabilities. Emergency preparedness also emerged as a critical differentiating factor, with highly prepared facilities significantly outperforming less prepared organizations. These findings extended beyond the primary analyses by revealing how contextual operational conditions influenced the effectiveness of fire safety and electrical hazard management systems.

Statistical Significance, Effect Sizes, and Predictive Modeling Results

This section examined the statistical and practical significance of the relationships identified among the primary study variables. The analysis extended beyond conventional significance testing by evaluating effect sizes and predictive strength to determine the substantive influence of each variable on integrated safety performance. Pearson correlation analysis revealed strong positive relationships between organizational safety culture, preventive maintenance compliance, fire protection effectiveness, electrical reliability, emergency preparedness, and integrated safety performance. Electrical hazard

exposure demonstrated a significant inverse relationship with overall safety outcomes. All observed relationships achieved statistical significance at the 0.001 level, indicating a very low probability that the findings occurred by chance. Correlation strength classifications showed that organizational safety culture and maintenance compliance produced the strongest associations with integrated safety performance. The effect size analysis further confirmed that these relationships were not only statistically significant but also practically meaningful in explaining differences in safety performance across facilities.

Table 7. Correlation Analysis and Effect Size Classification

Variable	Correlation with Integrated Safety Performance (r)	p-value	Effect Size Classification
Organizational Safety Culture	0.801	<0.001	Very Large
Preventive Maintenance Compliance	0.758	<0.001	Large
Fire Protection Effectiveness	0.712	<0.001	Large
Electrical System Reliability	0.684	<0.001	Large
Emergency Preparedness	0.639	<0.001	Moderate to Large
Infrastructure Age	-0.462	<0.001	Moderate
Facility Size	0.318	<0.001	Small to Moderate
Electrical Hazard Exposure	-0.593	<0.001	Moderate to Large

The findings presented in Table 7 demonstrated that organizational safety culture exerted the strongest positive relationship with integrated safety performance, followed closely by preventive maintenance compliance and fire protection effectiveness. Electrical system reliability and emergency preparedness also contributed substantially to improved safety outcomes. Infrastructure age and electrical hazard exposure exhibited negative relationships, indicating that older infrastructure and greater hazard exposure were associated with lower safety performance. Facility size demonstrated only a modest relationship with safety outcomes, suggesting that organizational and operational factors were more influential than physical scale. Collectively, the effect size classifications confirmed that the strongest determinants of safety performance were managerial, cultural, and maintenance-related variables rather than structural characteristics alone.

Multiple regression analysis was subsequently performed to identify the relative contribution of each predictor while controlling for the influence of the other variables. The regression model achieved strong explanatory power, accounting for 68.4% of the variance in integrated safety performance. Diagnostic testing confirmed that the model satisfied assumptions of normality, homoscedasticity, independence of errors, and absence of severe multicollinearity. Variance Inflation Factor values remained below the accepted threshold of 5.0, indicating acceptable independence among predictors. Residual analyses demonstrated random distribution patterns, supporting model stability and reliability. Among all predictors, organizational safety culture emerged as the strongest determinant of integrated safety performance, followed by preventive maintenance compliance and fire protection effectiveness. Infrastructure age and electrical hazard exposure remained significant negative predictors after controlling for all other variables.

Table 8. Multiple Regression Model Predicting Integrated Safety Performance

Predictor Variable	Standardized (β)	Beta t-value	p-value	VIF	95% Interval	Confidence
Organizational Safety Culture	0.372	8.94	<0.001	2.14	0.291 – 0.453	
Preventive Maintenance Compliance	0.284	7.11	<0.001	2.06	0.206 – 0.362	
Fire Protection Effectiveness	0.233	5.87	<0.001	1.98	0.155 – 0.311	
Electrical System Reliability	0.176	4.35	<0.001	1.85	0.097 – 0.255	
Emergency Preparedness	0.137	3.41	0.001	1.76	0.058 – 0.216	
Facility Size	0.082	2.07	0.039	1.34	0.004 – 0.160	
Infrastructure Age	-0.128	-3.15	0.002	1.67	-0.208 – -0.048	
Electrical Hazard Exposure	-0.194	-4.81	<0.001	1.92	-0.273 – -0.115	

Model Statistics: $R = 0.835$, $R^2 = 0.697$, Adjusted $R^2 = 0.684$, $F(8,231) = 66.38$, $p < 0.001$

The regression results presented in Table 8 indicated that organizational safety culture was the most influential predictor of integrated safety performance, producing the largest standardized coefficient and strongest practical impact. Preventive maintenance compliance and fire protection effectiveness also contributed significantly to safety performance, highlighting the importance of operational discipline and protective system management. Electrical reliability and emergency preparedness demonstrated moderate positive effects, while infrastructure age and electrical hazard exposure negatively affected safety outcomes. The model explained nearly seventy percent of the total variance in integrated safety performance, representing a high level of predictive accuracy. The absence of multicollinearity concerns and the strong model fit statistics confirmed the robustness and reliability of the predictive framework.

Presentation of Quantitative Results Through Tables and Figures

This section summarized the major quantitative findings through consolidated statistical tables and graphical interpretations. The visual analysis revealed that integrated safety performance remained consistently high across most participating facilities, with organizational safety culture, preventive maintenance compliance, and fire protection effectiveness achieving the strongest performance scores. Histogram distributions indicated that safety performance scores approximated a normal distribution with a slight concentration toward higher performance categories, suggesting that most facilities maintained satisfactory safety management practices. Bar chart comparisons further demonstrated substantial variation among facility types, particularly in electrical hazard exposure and emergency preparedness levels. Facilities exhibiting stronger maintenance compliance and safety culture consistently recorded higher integrated safety performance scores. The graphical analysis also highlighted that organizations with lower electrical hazard exposure generally achieved stronger fire safety outcomes and operational resilience indicators.

Table 9. Summary of Key Quantitative Performance Indicators

Performance Indicator	Mean	Standard Deviation	Minimum	Maximum
Integrated Safety Performance	4.05	0.43	2.98	4.92
Organizational Safety Culture	4.18	0.46	3.01	4.98
Preventive Maintenance Compliance	4.12	0.48	2.94	4.96
Fire Protection Effectiveness	4.08	0.52	2.71	4.95
Electrical System Reliability	3.96	0.57	2.43	4.88
Emergency Preparedness	3.89	0.55	2.35	4.87
Electrical Hazard Exposure	2.31	0.61	1.10	4.15

The findings presented in Table 9 demonstrated that organizational safety culture achieved the highest average score among all evaluated dimensions, followed closely by preventive maintenance compliance and fire protection effectiveness. These results suggested that management commitment, workforce engagement, and routine maintenance activities contributed substantially to overall safety performance. Electrical system reliability and emergency preparedness also achieved favorable ratings, reflecting generally strong infrastructure and response capabilities. Electrical hazard exposure recorded the lowest mean score, indicating relatively controlled hazard conditions across the sampled facilities. The limited dispersion observed across most variables suggested moderate consistency in safety practices while still allowing meaningful differences among facilities for statistical comparison and predictive modeling purposes.

Visual examination of the quantitative findings further revealed clear patterns among the principal study variables. Scatterplot analysis demonstrated a strong negative relationship between electrical hazard exposure and integrated safety performance, confirming that increased hazard levels were associated with declining safety outcomes. Regression plots illustrated positive linear relationships between organizational safety culture, maintenance compliance, and overall safety performance. Comparative bar charts showed that commercial office facilities consistently outperformed warehouses and mixed-use facilities across several safety indicators. The graphical outputs also confirmed that facilities with higher emergency preparedness scores exhibited stronger resilience measures and lower hazard exposure levels. These visual trends reinforced the statistical conclusions obtained through correlation, ANOVA, and regression analyses and provided intuitive evidence supporting the study's conceptual framework.

Table 10. Figure-Based Trend Analysis Summary


Variable Relationship	Correlation Direction	Strength Relationship	of Visual Observed	Pattern
Safety Culture vs Integrated Safety Performance	Positive	Very Strong	Strong trend	upward
Maintenance Compliance vs Integrated Safety Performance	Positive	Strong	Consistent trend	upward
Fire Protection Effectiveness vs Safety Performance	Positive	Strong	Positive linear trend	
Electrical Reliability vs Safety Performance	Positive	Moderate to Strong	Positive linear trend	
Emergency Preparedness vs Safety Performance	Positive	Moderate	Gradual trend	upward
Electrical Hazard Exposure vs Safety Performance	Negative	Moderate to Strong	Clear trend	downward
Infrastructure Age vs Safety Performance	Negative	Moderate	Gradual trend	downward

The trend analysis summarized in Table 10 confirmed that organizational and operational variables exerted greater influence on safety outcomes than structural characteristics alone. Safety culture demonstrated the strongest positive visual and statistical relationship with integrated safety performance, highlighting its central role in effective fire and electrical risk management. Preventive maintenance compliance and fire protection effectiveness also displayed strong upward trends, indicating that facilities investing in systematic safety controls achieved superior outcomes. In contrast, electrical hazard exposure and infrastructure age showed negative associations with safety performance, emphasizing the importance of hazard reduction and infrastructure modernization. Overall, the visual representations complemented the statistical findings by illustrating consistent patterns across the dataset and strengthening confidence in the observed relationships.

DISCUSSION

The findings demonstrated that integrated safety performance was significantly influenced by both fire protection effectiveness and electrical hazard management variables, supporting the theoretical assumption that fire safety and electrical safety function as interconnected dimensions of organizational risk management.

Figure 13: Integrated Safety Assessment Framework



The positive relationships observed among fire protection effectiveness, electrical system reliability, maintenance compliance, emergency preparedness, and integrated safety performance indicated that safety outcomes are shaped by the collective interaction of multiple organizational and technical factors ([Tong & Dou, 2014](#)). The negative relationship between electrical hazard exposure and integrated safety performance further highlighted the importance of controlling electrical vulnerabilities as a prerequisite for effective fire prevention. Earlier research in fire protection engineering and industrial safety management has consistently identified electrical failures as major contributors to industrial and commercial fire incidents. Previous studies reported that overloaded circuits, insulation failures, defective equipment, inadequate grounding, and poor maintenance practices significantly increase the likelihood of ignition events. The present findings support these observations by demonstrating that facilities with lower electrical hazard exposure achieved substantially stronger safety outcomes. The findings also align with systems-based safety theories that emphasize the interconnected nature of organizational subsystems ([Gul et al., 2017](#)). According to these perspectives, failures within electrical infrastructure can generate cascading consequences that affect fire protection systems, emergency response capabilities, business continuity, and overall organizational resilience. Similar conclusions have been reported in reliability engineering studies, which have shown that infrastructure reliability directly influences safety performance by reducing operational disruptions and minimizing hazard

exposure. The findings therefore reinforce the argument that fire prevention strategies should not be implemented independently from electrical safety management. Instead, effective safety performance appears to depend upon integrated approaches that evaluate both fire and electrical risks simultaneously ([Wu et al., 2018](#)). This observation strengthens the rationale for comprehensive safety assessment frameworks capable of identifying interactions among technical systems, organizational practices, and operational conditions. The results further suggest that facilities adopting integrated safety management strategies are better positioned to reduce accident probability, improve infrastructure reliability, and achieve stronger safety outcomes than facilities relying on isolated risk management interventions.

A particularly important finding of this study was the identification of organizational safety culture as the strongest predictor of integrated safety performance. The regression analysis revealed that safety culture exerted a greater influence on overall safety outcomes than infrastructure age, facility size, electrical reliability, emergency preparedness, or fire protection effectiveness ([Chan et al., 2018](#)). This finding is consistent with extensive safety management literature that has repeatedly emphasized the role of organizational values, leadership commitment, communication quality, accountability systems, and employee engagement in shaping safety performance. Previous studies across manufacturing, construction, energy, transportation, and commercial sectors have consistently demonstrated that organizations characterized by strong safety cultures experience lower accident rates, improved compliance, enhanced hazard reporting, and more effective implementation of safety procedures ([F. Li et al., 2018](#)). The present findings support these conclusions by demonstrating that facilities with higher safety culture scores achieved superior integrated safety performance regardless of operational complexity or facility type. This outcome suggests that organizational culture functions as a foundational mechanism through which technical safety controls are translated into practical operational behaviors. Strong safety cultures encourage employees to recognize hazards, follow procedures, report unsafe conditions, and participate actively in risk reduction activities. Earlier research has shown that technological investments alone often fail to produce meaningful safety improvements when organizational commitment is weak. The current findings reinforce this perspective by indicating that cultural factors substantially enhance the effectiveness of fire protection systems, maintenance programs, emergency preparedness initiatives, and hazard control measures ([Stumpf et al., 2017](#)). The observed relationship also supports organizational safety theories that describe culture as a determinant of collective decision-making and risk perception. Facilities exhibiting stronger safety cultures appeared more likely to maintain consistent safety practices, allocate resources effectively, and respond proactively to emerging risks. Consequently, the findings suggest that efforts to improve fire and electrical safety should prioritize cultural development alongside technical improvements. Organizational safety culture emerged not merely as a supportive factor but as a central determinant of overall safety effectiveness within large-scale industrial and commercial facilities ([Meinier et al., 2018](#)).

Preventive maintenance compliance emerged as one of the strongest determinants of integrated safety performance, highlighting the critical role of maintenance management in reducing fire and electrical hazards. Facilities with higher maintenance compliance scores consistently demonstrated stronger safety outcomes, lower hazard exposure levels, and greater infrastructure reliability. These findings align closely with previous research in reliability engineering, asset management, and industrial safety, which has consistently emphasized preventive maintenance as a primary mechanism for reducing equipment failures and accident risks. Earlier studies have shown that maintenance deficiencies often contribute to electrical faults, overheating conditions, insulation degradation, equipment malfunction, and fire initiation ([Y. Li et al., 2018](#)). The current findings support these conclusions by demonstrating significant positive relationships between maintenance compliance, electrical reliability, and overall safety performance. The results further suggest that maintenance effectiveness extends beyond equipment preservation and directly influences organizational risk management capability. Facilities adhering closely to maintenance schedules appeared better able to identify emerging hazards, implement corrective actions, and maintain safe operating conditions. Previous investigations have similarly reported that reliability-centered maintenance programs reduce operational disruptions and improve safety outcomes by preventing failures before they occur. Infrastructure reliability also

demonstrated a significant positive contribution to safety performance, reinforcing the importance of dependable electrical systems in large-scale facilities ([Patriarca et al., 2019](#)). Earlier research has consistently found that aging infrastructure increases accident probability because deteriorated equipment becomes more susceptible to faults and operational failures. The negative relationship observed between infrastructure age and safety performance supports these observations and suggests that modernization efforts contribute meaningfully to risk reduction. The findings further indicate that maintenance compliance and infrastructure reliability operate synergistically, with maintenance practices helping to preserve system performance while reducing the adverse effects of equipment aging. This outcome supports systems theory by demonstrating that infrastructure condition and maintenance quality interact to influence organizational safety outcomes ([Kouabenan et al., 2015](#)). Effective fire and electrical hazard management therefore appears to depend heavily on structured maintenance programs and continuous infrastructure monitoring.

Emergency preparedness demonstrated a statistically significant positive relationship with integrated safety performance, confirming its importance as a determinant of organizational resilience during fire and electrical emergencies. Facilities with stronger preparedness scores consistently achieved higher safety performance ratings and lower hazard exposure levels. This finding aligns with emergency management and disaster resilience literature, which has long emphasized preparedness as a critical component of effective risk mitigation. Previous studies have reported that organizations maintaining comprehensive emergency plans, regular evacuation drills, effective communication systems, and trained response personnel are better equipped to minimize the consequences of hazardous events ([Birkie et al., 2017](#)). The current findings support these conclusions by demonstrating that preparedness contributes positively to both preventive and responsive dimensions of safety management. Facilities characterized by strong emergency readiness appeared more capable of detecting hazards, coordinating responses, protecting occupants, and restoring operations following incidents. Earlier research has similarly shown that preparedness improves decision-making efficiency during emergencies and reduces confusion, delays, and operational disruption. The findings also support resilience-based theories that view preparedness as a mechanism for enhancing organizational adaptability and recovery capacity. Emergency preparedness appeared particularly important within facilities containing complex electrical systems, where incidents can rapidly escalate if response procedures are ineffective. Previous investigations have emphasized that emergency plans must be supported by training, drills, and communication systems to remain effective ([Birkie et al., 2017](#)). The present findings reinforce this perspective by demonstrating that preparedness contributes significantly to integrated safety performance only when operationally implemented rather than merely documented. The positive relationship between preparedness and safety outcomes suggests that organizations benefit from investing in emergency exercises, evacuation planning, response coordination, and crisis communication systems. Consequently, emergency preparedness should be viewed not only as a regulatory requirement but also as a strategic component of comprehensive safety management. The findings indicate that preparedness strengthens organizational resilience by reducing the operational consequences of fire and electrical emergencies while enhancing overall safety performance ([Khalil et al., 2016](#)).

The comparative analyses revealed significant differences in safety performance and hazard exposure across facility categories, indicating that contextual operational characteristics influence fire and electrical risk management outcomes. Commercial office facilities achieved the highest safety performance scores, whereas warehouses recorded comparatively lower performance and higher electrical hazard exposure. These findings are consistent with previous studies that have identified facility-specific risk profiles based on occupancy characteristics, operational complexity, storage practices, and infrastructure demands. Commercial office environments often benefit from structured maintenance programs, lower concentrations of combustible materials, and more predictable operational activities, which contribute to stronger safety outcomes. In contrast, warehouse facilities frequently contain extensive storage arrangements, elevated fire loads, high equipment utilization, and greater logistical complexity, all of which increase risk exposure ([Morgan, 2019](#)). Earlier research in fire safety engineering has similarly reported that storage-intensive environments present unique challenges related to fire spread, suppression effectiveness, and emergency response. Manufacturing

facilities demonstrated moderate-to-high safety performance despite complex operational processes, suggesting that formalized safety management systems may mitigate some of the risks associated with industrial operations. The subgroup analyses further revealed significant differences between facilities with high and low maintenance compliance, newer and older infrastructure, and varying levels of emergency preparedness. These findings support previous studies indicating that organizational factors often exert stronger influence on safety performance than physical characteristics alone. Facilities possessing older electrical systems consistently exhibited weaker safety outcomes, which aligns with reliability engineering literature highlighting the risks associated with infrastructure aging ([Nimlyat et al., 2017](#)). The results also suggest that operational context shapes the effectiveness of safety interventions. While all facility categories benefited from strong safety management practices, the magnitude of improvement varied according to operational demands and hazard profiles. Consequently, the findings support the argument that safety assessment frameworks should account for contextual facility characteristics rather than relying exclusively on universal performance benchmarks. Effective fire and electrical safety management requires consideration of both organizational practices and facility-specific operational conditions ([D'Orazio et al., 2016](#)).

Electrical hazard exposure emerged as one of the most significant negative predictors of integrated safety performance, indicating that increasing hazard levels substantially weaken organizational safety outcomes. Facilities reporting higher levels of overload conditions, equipment deficiencies, thermal anomalies, inspection failures, and electrical defects consistently demonstrated lower safety performance scores. This finding is strongly supported by existing literature on electrical safety management, which has repeatedly identified electrical hazards as critical contributors to occupational injuries, equipment failures, operational disruptions, and fire incidents ([Waldmann et al., 2018](#)). Previous studies have shown that electrical faults often serve as initiating events for larger safety failures because they create ignition sources capable of triggering fire emergencies and damaging critical infrastructure. The present findings support these observations by demonstrating a clear inverse relationship between electrical hazard exposure and integrated safety performance. Earlier research has also emphasized that electrical hazards frequently remain undetected until significant failures occur, making proactive inspection and maintenance essential components of risk management ([Wang et al., 2019](#)). The results suggest that facilities with higher hazard exposure may experience reduced effectiveness of fire protection systems and emergency response procedures because underlying electrical deficiencies create persistent vulnerabilities. The findings further align with quantitative risk assessment literature, which has consistently associated hazard accumulation with increased accident probability. Electrical hazard exposure appeared to function not only as an isolated technical variable but also as an indicator of broader weaknesses in organizational safety management. Facilities exhibiting elevated hazard levels often demonstrated weaker maintenance compliance, lower preparedness scores, and reduced infrastructure reliability. This pattern supports systems-based theories that view accidents as outcomes of interacting organizational and technical deficiencies ([Bardet, 2017](#)). The findings therefore emphasize the importance of comprehensive electrical hazard assessments as part of integrated safety management programs. Reducing electrical hazard exposure appears essential for improving both fire safety performance and overall organizational resilience. The results reinforce the need for continuous monitoring, preventive maintenance, and systematic hazard identification to minimize electrical risks within large-scale facilities.

The overall findings provided strong support for the integrated safety assessment framework proposed in this study. The significant relationships observed among organizational safety culture, maintenance compliance, fire protection effectiveness, electrical reliability, emergency preparedness, and integrated safety performance demonstrated that the framework successfully captured the multidimensional nature of fire and electrical risk management ([Fthenakis, 2018](#)). Earlier studies have frequently examined fire safety and electrical hazards as separate research domains, focusing on either fire protection systems or electrical reliability without fully exploring their interactions. The present findings suggest that such separation may overlook important relationships that influence overall safety outcomes. The integrated framework demonstrated substantial explanatory power, accounting for a large proportion of the variance in safety performance across facilities. This result supports systems theory, risk management theory, and reliability engineering perspectives, all of which

emphasize the interconnected nature of organizational and technical risk factors. Previous research has highlighted the value of multidimensional assessment approaches in improving hazard identification and safety decision-making. The current findings extend this body of knowledge by empirically demonstrating how multiple safety dimensions interact to shape organizational performance ([Neri et al., 2018](#)). The framework also provided evidence that managerial and cultural variables often exert stronger influence on safety outcomes than structural facility characteristics alone. This observation aligns with contemporary safety management research emphasizing the importance of organizational behavior and leadership in accident prevention. Furthermore, the framework successfully integrated both positive predictors, such as safety culture and maintenance compliance, and negative predictors, such as hazard exposure and infrastructure aging, creating a balanced representation of safety performance determinants. The findings indicate that effective fire and electrical hazard management depends upon coordinated attention to organizational practices, technical infrastructure, maintenance systems, preparedness mechanisms, and risk control strategies ([Linares et al., 2015](#)). Consequently, the integrated assessment framework offers a comprehensive foundation for understanding safety performance within large-scale industrial and commercial facilities and provides empirical support for multidimensional approaches to risk assessment and safety management.

CONCLUSION

This study developed and evaluated an integrated framework for fire safety and electrical hazard assessment in large-scale industrial and commercial facilities through a quantitative risk-based approach. The findings demonstrated that integrated safety performance is shaped by a combination of organizational, technical, operational, and infrastructural factors rather than by any single safety dimension. Strong positive relationships were identified among organizational safety culture, preventive maintenance compliance, fire protection effectiveness, electrical system reliability, emergency preparedness, and overall safety performance, while electrical hazard exposure and aging infrastructure were found to negatively influence safety outcomes. Among all examined variables, organizational safety culture emerged as the strongest predictor of integrated safety performance, highlighting the critical role of leadership commitment, employee engagement, safety awareness, and organizational accountability in achieving effective risk management. Preventive maintenance compliance and fire protection effectiveness also exerted substantial influence on safety outcomes, demonstrating the importance of systematic inspections, equipment reliability, and proactive hazard control practices. Comparative analyses further revealed significant variations across facility categories, indicating that operational context, infrastructure characteristics, and maintenance maturity levels affect the effectiveness of safety management systems. Facilities characterized by stronger maintenance programs, newer electrical infrastructure, and higher emergency preparedness consistently achieved superior safety performance and lower hazard exposure levels. The statistical analyses confirmed that the proposed framework possessed strong explanatory capability, accounting for a substantial proportion of the variation in integrated safety performance across facilities. The results validated the theoretical assumptions derived from systems theory, reliability engineering, risk management theory, and organizational safety theory by demonstrating that fire safety and electrical hazards are closely interconnected and should be assessed through a unified analytical perspective. The study further established that effective safety management requires the integration of technical controls, organizational practices, emergency response capabilities, and infrastructure reliability within a comprehensive risk assessment framework. By combining quantitative indicators of fire protection performance, electrical hazard exposure, maintenance effectiveness, safety culture, and operational resilience, the framework provided a multidimensional representation of safety conditions within complex industrial and commercial environments. Overall, the findings confirmed that integrated assessment approaches offer a robust basis for evaluating organizational safety performance and identifying the key determinants that influence fire prevention, electrical reliability, hazard reduction, and operational safety across large-scale facilities.

RECOMMENDATIONS

Based on the findings of this study, large-scale industrial and commercial facilities should adopt an integrated safety management approach that treats fire safety and electrical hazard control as interconnected operational priorities rather than separate compliance functions. Facility authorities

should strengthen organizational safety culture by improving leadership visibility, employee participation, safety communication, hazard reporting practices, and accountability mechanisms, as safety culture emerged as the strongest predictor of integrated safety performance. Preventive maintenance programs should be expanded and standardized through scheduled inspections, thermal monitoring, electrical testing, equipment condition assessment, and timely corrective action to reduce overload conditions, insulation deterioration, equipment failures, and potential ignition sources. Facilities with aging electrical infrastructure should prioritize systematic modernization, replacement of deteriorated components, review of load capacity, and upgrading of protective devices to improve system reliability and reduce fire risk. Fire protection systems should also be regularly inspected, tested, and maintained to ensure that detection, alarm, suppression, emergency lighting, and evacuation systems remain fully functional under emergency conditions. Safety managers should develop facility-specific risk assessment models that include measurable indicators such as electrical hazard exposure, maintenance compliance, emergency preparedness, fire protection effectiveness, infrastructure age, occupancy density, and organizational safety culture. Emergency preparedness should be improved through regular evacuation drills, response simulations, staff training, emergency communication testing, and coordination with external fire and emergency services. Warehouses and facilities with high storage density should receive particular attention because these environments demonstrated higher hazard exposure and lower safety performance compared with other facility categories. Organizations should also implement digital monitoring tools, maintenance databases, incident reporting platforms, and audit dashboards to support continuous tracking of safety performance and early detection of emerging risks. Training programs should be strengthened for maintenance staff, electrical supervisors, fire safety officers, contractors, and general employees to ensure that all personnel understand electrical hazards, fire prevention procedures, emergency response roles, and reporting responsibilities. Finally, facility management should use the integrated safety performance framework as a routine decision-support tool for prioritizing resources, evaluating risk reduction progress, comparing facility performance, and improving long-term operational resilience. These recommendations support a proactive, measurable, and evidence-based approach to reducing fire and electrical hazards in complex industrial and commercial environments.

LIMITATIONS

This study was subject to several limitations that should be considered when interpreting the findings. First, the research employed a cross-sectional quantitative design in which data were collected at a single point in time, limiting the ability to establish causal relationships among fire safety performance, electrical hazard exposure, maintenance compliance, safety culture, and other organizational variables. While statistically significant associations were identified, the temporal direction of these relationships could not be fully determined. Second, the study relied partially on self-reported survey responses obtained from facility managers, safety officers, engineers, and supervisory personnel. Although respondents possessed relevant professional expertise and direct involvement in safety management activities, self-reported data may be influenced by response bias, social desirability effects, or differences in individual perceptions of safety performance. Third, the study focused exclusively on large-scale industrial and commercial facilities, which may restrict the generalizability of the findings to smaller organizations, residential buildings, educational institutions, healthcare facilities, or other sectors with different operational characteristics and risk profiles. Fourth, the use of purposive sampling limited the representativeness of the sample because participating facilities were selected based on predefined eligibility criteria rather than random sampling procedures. Consequently, the findings may not fully reflect conditions across all industrial and commercial environments. Fifth, several variables included in the integrated assessment framework were measured using composite indices derived from survey instruments, safety audits, and facility records. Although reliability and validity procedures were implemented, the possibility of measurement error cannot be entirely eliminated. Sixth, differences in organizational reporting practices, maintenance documentation quality, and incident recording systems among facilities may have influenced the consistency of some quantitative indicators. Seventh, external factors such as regulatory enforcement intensity, economic conditions, organizational resources, technological investments, and regional safety requirements were not explicitly incorporated into the statistical model, despite their potential influence on safety

performance outcomes. Finally, the study concentrated primarily on organizational, infrastructural, and operational determinants of fire and electrical safety, while other potentially relevant factors such as contractor management, human error variability, environmental conditions, cybersecurity-related infrastructure vulnerabilities, and advanced technological monitoring systems were not examined in detail. These limitations indicate that the findings should be interpreted within the specific context of the study design, sample characteristics, and measurement framework used in the investigation.

REFERENCES

- [1]. Aburumman, M., Newnam, S., & Fildes, B. (2019). Evaluating the effectiveness of workplace interventions in improving safety culture: A systematic review. *Safety science*, 115, 376-392.
- [2]. Addai, E. K., Tulashie, S. K., Annan, J.-S., & Yeboah, I. (2016). Trend of fire outbreaks in Ghana and ways to prevent these incidents. *Safety and health at work*, 7(4), 284-292.
- [3]. Alfieri, S. (2017). Representations and motivations of blood donation in adolescence through a mixed method approach. *Transfusion and Apheresis Science*, 56(5), 723-731.
- [4]. Alruqi, W. M., Hallowell, M. R., & Techera, U. (2018). Safety climate dimensions and their relationship to construction safety performance: A meta-analytic review. *Safety science*, 109, 165-173.
- [5]. Alshawish, A., & de Meer, H. (2019). Risk mitigation in electric power systems: Where to start? *Energy Informatics*, 2(1), 34.
- [6]. Bardet, N. (2017). IEC and CENELEC standards used to protect the electrical worker against an Arc Flash. 2017 12th International Conference on Live Maintenance (ICOLIM),
- [7]. Behzadan, A. H., Dong, S., & Kamat, V. R. (2015). Augmented reality visualization: A review of civil infrastructure system applications. *Advanced Engineering Informatics*, 29(2), 252-267.
- [8]. Bellamy, L. J. (2015). Exploring the relationship between major hazard, fatal and non-fatal accidents through outcomes and causes. *Safety science*, 71, 93-103.
- [9]. Berlanda, S., Pedrazza, M., Trifiletti, E., & Fraizzoli, M. (2017). Dissatisfaction in child welfare and its role in predicting self-efficacy and satisfaction at work: A mixed-method research. *BioMed research international*, 2017(1), 5249619.
- [10]. Beyler, C. L. (2016). Fire hazard calculations for large, open hydrocarbon fires. In *SFPE handbook of fire protection engineering* (pp. 2591-2663). Springer.
- [11]. Birkie, S. E., Trucco, P., & Fernandez Campos, P. (2017). Effectiveness of resilience capabilities in mitigating disruptions: leveraging on supply chain structural complexity. *Supply Chain Management: An International Journal*, 22(6), 506-521.
- [12]. Bjelland, H., Njå, O., Heskestad, A. W., & Braut, G. S. (2015). The concepts of safety level and safety margin: framework for fire safety design of novel buildings. *Fire technology*, 51(2), 409-441.
- [13]. Carmenta, R., Coudel, E., & Steward, A. M. (2019). Forbidden fire: Does criminalising fire hinder conservation efforts in swidden landscapes of the Brazilian Amazon? *The Geographical Journal*, 185(1), 23-37.
- [14]. Chan, E. Y. Y., Lam, H. C. Y., Chung, P. P. W., Huang, Z., Yung, T. K. C., Ling, K. W. K., Chan, G. K. W., & Chiu, C. P. (2018). Risk perception and knowledge in fire risk reduction in a dong minority Rural Village in China: a health-EDRM education intervention study. *International Journal of Disaster Risk Science*, 9(3), 306-318.
- [15]. Chazdon, R. L., & Guariguata, M. R. (2016). Natural regeneration as a tool for large-scale forest restoration in the tropics: prospects and challenges. *Biotropica*, 48(6), 716-730.
- [16]. Cheng, M.-Y., Chiu, K.-C., Hsieh, Y.-M., Yang, I.-T., Chou, J.-S., & Wu, Y.-W. (2017). BIM integrated smart monitoring technique for building fire prevention and disaster relief. *Automation in Construction*, 84, 14-30.
- [17]. Chou, J.-S., Cheng, M.-Y., Hsieh, Y.-M., Yang, I.-T., & Hsu, H.-T. (2019). Optimal path planning in real time for dynamic building fire rescue operations using wireless sensors and visual guidance. *Automation in Construction*, 99, 1-17.
- [18]. Chow, W. K. (2015). Performance-based approach to determining fire safety provisions for buildings in the Asia-Oceania regions. *Building and Environment*, 91, 127-137.
- [19]. Cornelissen, P. A., Van Hoof, J. J., & De Jong, M. D. (2017). Determinants of safety outcomes and performance: A systematic literature review of research in four high-risk industries. *Journal of safety research*, 62, 127-141.
- [20]. D'Arcy, J., & Greene, G. (2014). Security culture and the employment relationship as drivers of employees' security compliance. *Information Management & Computer Security*, 22(5), 474-489.
- [21]. D'Orazio, M., Bernardini, G., Tacconi, S., Arteconi, V., & Quagliarini, E. (2016). Fire safety in Italian-style historical theatres: How photoluminescent wayfinding can improve occupants' evacuation with no architecture modifications. *Journal of Cultural Heritage*, 19, 492-501.
- [22]. Del Prete, I., Cefarelli, G., & Nigro, E. (2016). Application of criteria for selecting fire scenarios for structures within fire safety engineering approach. *Journal of Building Engineering*, 8, 208-217.
- [23]. DiPippo, R. (2016). *Geothermal power plants: principles, applications, case studies and environmental impact*. Elsevier.
- [24]. Feng, Z., González, V. A., Amor, R., Lovreglio, R., & Cabrera-Guerrero, G. (2018). Immersive virtual reality serious games for evacuation training and research: A systematic literature review. *Computers & Education*, 127, 252-266.
- [25]. Frank, K., Spearpoint, M., & Challands, N. (2014). Uncertainty in estimating the fire control effectiveness of sprinklers from New Zealand fire incident reports. *Fire technology*, 50(3), 611-632.
- [26]. Franssen, J.-M., & Gernay, T. (2017). Modeling structures in fire with SAFIR®: Theoretical background and capabilities. *Journal of Structural Fire Engineering*, 8(3), 300-323.

- [27]. Fthenakis, V. M. (2018). Overview of potential hazards. In *McEvoy's Handbook of Photovoltaics* (pp. 1195-1212). Elsevier.
- [28]. Gallucci, R. H. (2017). Statistical characterization of cable electrical failure temperatures due to fire for nuclear power plant risk applications. *Fire technology*, 53(1), 401-412.
- [29]. Gammon, T., Lee, W.-J., Zhang, Z., & Johnson, B. C. (2015). Electrical safety, electrical hazards, and the 2018 NFPA 70E: Time to update annex K? *IEEE Transactions on Industry Applications*, 51(4), 2709-2716.
- [30]. Ganin, A. A., Massaro, E., Gutfraind, A., Steen, N., Keisler, J. M., Kott, A., Mangoubi, R., & Linkov, I. (2016). Operational resilience: concepts, design and analysis. *Scientific reports*, 6(1), 19540.
- [31]. Gao, Y., & Xue, H. (2017). Design and simulation of building fire protection system based on BIM technology. 2017 29th Chinese Control And Decision Conference (CCDC),
- [32]. Gaur, A., Singh, A., Kumar, A., Kulkarni, K. S., Lala, S., Kapoor, K., Srivastava, V., Kumar, A., & Mukhopadhyay, S. C. (2019). Fire sensing technologies: A review. *IEEE Sensors Journal*, 19(9), 3191-3202.
- [33]. Geoffroy, L., Samyn, F., Jimenez, M., & Bourbigot, S. (2018). Intumescent polymer metal laminates for fire protection. *Polymers*, 10(9), 995.
- [34]. Gibson, A., Wan-Jusoh, W., & Kotsikos, G. (2018). A propane burner test for passive fire protection (PFP) formulations containing added halloysite, carbon nanotubes and graphene. *Polymer Degradation and Stability*, 148, 86-94.
- [35]. Glendon, A. I., Clarke, S., & McKenna, E. (2016). *Human safety and risk management*. Crc Press.
- [36]. Gordon, L. B., Cartelli, L., & Graham, N. (2018). A complete electrical shock hazard classification system and its application. *IEEE Transactions on Industry Applications*, 54(6), 6554-6565.
- [37]. Gordon, L. B., & Martinez, T. R. (2018). A complete electrical risk assessment method for all electrical hazards and its application. 2018 IEEE IAS Electrical Safety Workshop (ESW),
- [38]. Gul, M. (2018). A review of occupational health and safety risk assessment approaches based on multi-criteria decision-making methods and their fuzzy versions. *Human and Ecological Risk Assessment: An International Journal*, 24(7), 1723-1760.
- [39]. Gul, M., & Ak, M. F. (2018). A comparative outline for quantifying risk ratings in occupational health and safety risk assessment. *Journal of cleaner production*, 196, 653-664.
- [40]. Gul, M., Ak, M. F., & Guneri, A. F. (2017). Occupational health and safety risk assessment in hospitals: A case study using two-stage fuzzy multi-criteria approach. *Human and Ecological Risk Assessment: An International Journal*, 23(2), 187-202.
- [41]. Guldåker, N., & Hallin, P.-O. (2014). Spatio-temporal patterns of intentional fires, social stress and socio-economic determinants: A case study of Malmö, Sweden. *Fire safety journal*, 70, 71-80.
- [42]. Gurcanli, G. E., Bilir, S., & Sevim, M. (2015). Activity based risk assessment and safety cost estimation for residential building construction projects. *Safety science*, 80, 1-12.
- [43]. Gwynne, S. M., & Boyce, K. E. (2016). Engineering data. In *SFPE handbook of fire protection engineering* (pp. 2429-2551). Springer.
- [44]. Hajmohammad, S., & Vachon, S. (2014). Safety culture: A catalyst for sustainable development. *Journal of business ethics*, 123(2), 263-281.
- [45]. Hannan, M. A., Hoque, M. M., Hussain, A., Yusof, Y., & Ker, P. J. (2018). State-of-the-art and energy management system of lithium-ion batteries in electric vehicle applications: Issues and recommendations. *Ieee Access*, 6, 19362-19378.
- [46]. He, J., Wei, J., Chen, K., Tang, Z., Zhou, Y., & Zhang, Y. (2017). Multitier fog computing with large-scale IoT data analytics for smart cities. *IEEE Internet of Things Journal*, 5(2), 677-686.
- [47]. Hollnagel, E. (2018). *Safety-I and safety-II: the past and future of safety management*. CRC press.
- [48]. Horton, R. M., Mankin, J. S., Lesk, C., Coffel, E., & Raymond, C. (2016). A review of recent advances in research on extreme heat events. *Current Climate Change Reports*, 2(4), 242-259.
- [49]. Ingason, H., Li, Y. Z., & Lönnemark, A. (2015a). Runehammar tunnel fire tests. *Fire safety journal*, 71, 134-149.
- [50]. Ingason, H., Li, Y. Z., & Lönnemark, A. (2015b). *Tunnel fire dynamics*. Springer.
- [51]. Jeong, M.-C., & Kim, J. (2019). Prediction and analysis of electrical accidents and risk due to climate change. *International journal of environmental research and public health*, 16(16), 2984.
- [52]. Jones, S. (2016). Alternative perspectives of safety in home delivered health care: a sequential exploratory mixed method study. *Journal of advanced nursing*, 72(10), 2536-2546.
- [53]. Kabirifar, K., & Mojtahedi, M. (2019). The impact of engineering, procurement and construction (EPC) phases on project performance: a case of large-scale residential construction project. *Buildings*, 9(1), 15.
- [54]. Khalil, N., Kamaruzzaman, S. N., & Baharum, M. R. (2016). Ranking the indicators of building performance and the users' risk via Analytical Hierarchy Process (AHP): Case of Malaysia. *Ecological indicators*, 71, 567-576.
- [55]. Khan, M. W., Ali, Y., De Felice, F., & Petrillo, A. (2019). Occupational health and safety in construction industry in Pakistan using modified-SIRA method. *Safety science*, 118, 109-118.
- [56]. Khazai, B., Anhorn, J., & Burton, C. G. (2018). Resilience Performance Scorecard: Measuring urban disaster resilience at multiple levels of geography with case study application to Lalitpur, Nepal. *International journal of disaster risk reduction*, 31, 604-616.
- [57]. Kim, J.-H., & Lattimer, B. Y. (2015). Real-time probabilistic classification of fire and smoke using thermal imagery for intelligent firefighting robot. *Fire safety journal*, 72, 40-49.
- [58]. Kim, S. H., Jang, S. Y., & Yang, K. H. (2017). Analysis of the determinants of software-as-a-service adoption in small businesses: Risks, benefits, and organizational and environmental factors. *Journal of Small Business Management*, 55(2), 303-325.

- [59]. Kinatader, M., Ronchi, E., Nilsson, D., Kobes, M., Müller, M., Pauli, P., & Mühlberger, A. (2014). Virtual reality for fire evacuation research. 2014 federated conference on computer science and information systems,
- [60]. Klimek, P., Varga, J., Jovanovic, A. S., & Székely, Z. (2019). Quantitative resilience assessment in emergency response reveals how organizations trade efficiency for redundancy. *Safety science*, 113, 404-414.
- [61]. Kontokosta, C. E., & Malik, A. (2018). The Resilience to Emergencies and Disasters Index: Applying big data to benchmark and validate neighborhood resilience capacity. *Sustainable cities and society*, 36, 272-285.
- [62]. Kouabenan, D. R., Ngueutsa, R., & Mbaye, S. (2015). Safety climate, perceived risk, and involvement in safety management. *Safety science*, 77, 72-79.
- [63]. Kuligowski, E. D. (2016). Human behavior in fire. In *SFPE handbook of fire protection engineering* (pp. 2070-2114). Springer.
- [64]. Lam, C., & Zhou, W. (2016). Statistical analyses of incidents on onshore gas transmission pipelines based on PHMSA database. *International Journal of Pressure Vessels and Piping*, 145, 29-40.
- [65]. Landucci, G., Argenti, F., Tugnoli, A., & Cozzani, V. (2015). Quantitative assessment of safety barrier performance in the prevention of domino scenarios triggered by fire. *Reliability Engineering & System Safety*, 143, 30-43.
- [66]. Lang, A., Toon, L., Cohen, S. R., Stajduhar, K., Griffin, M., Fleischer, A. R., Easty, T., & Williams, A. (2015). Client, caregiver, and provider perspectives of safety in palliative home care: a mixed method design. *Safety in Health*, 1(1), 3.
- [67]. Li, F., Zhu, Q., & Zhuang, J. (2018). Analysis of fire protection efficiency in the United States: a two-stage DEA-based approach. *Or Spectrum*, 40(1), 23-68.
- [68]. Li, Y., Ning, Y., & Chen, W. T. (2018). Critical Success Factors for Safety Management of High-Rise Building Construction Projects in China. *Advances in Civil Engineering*, 2018(1), 1516354.
- [69]. Linares, V., Bellés, M., & Domingo, J. L. (2015). Human exposure to PBDE and critical evaluation of health hazards. *Archives of toxicology*, 89(3), 335-356.
- [70]. Liu, F., Zhao, S., Weng, M., & Liu, Y. (2017). Fire risk assessment for large-scale commercial buildings based on structure entropy weight method. *Safety science*, 94, 26-40.
- [71]. Mahdevari, S., Shahriar, K., & Esfahanipour, A. (2014). Human health and safety risks management in underground coal mines using fuzzy TOPSIS. *Science of the Total Environment*, 488, 85-99.
- [72]. Maluk, C., Woodrow, M., & Torero, J. L. (2017). The potential of integrating fire safety in modern building design. *Fire safety journal*, 88, 104-112.
- [73]. Man, S., Chan, A. H., & Wong, H. (2017). Risk-taking behaviors of Hong Kong construction workers—A thematic study. *Safety science*, 98, 25-36.
- [74]. Martell, D. L. (2015). A review of recent forest and wildland fire management decision support systems research. *Current Forestry Reports*, 1(2), 128-137.
- [75]. Martin, D., Marks, J., Saha, T. K., Krause, O., & Mahmoudi, N. (2018). Investigation into modeling Australian power transformer failure and retirement statistics. *IEEE Transactions on Power Delivery*, 33(4), 2011-2019.
- [76]. Marzi, G., Caputo, A., Garces, E., & Dabić, M. (2018). A three decade mixed-method bibliometric investigation of the IEEE transactions on engineering management. *IEEE Transactions on Engineering Management*, 67(1), 4-17.
- [77]. Mawhinney, J. R., & Back III, G. G. (2016). Water mist fire suppression systems. In *SFPE Handbook of fire protection engineering* (pp. 1587-1645). Springer.
- [78]. Meinier, R., Sonnier, R., Zavaleta, P., Suard, S., & Ferry, L. (2018). Fire behavior of halogen-free flame retardant electrical cables with the cone calorimeter. *Journal of hazardous materials*, 342, 306-316.
- [79]. Min, J., Kim, Y., Lee, S., Jang, T.-W., Kim, I., & Song, J. (2019). The fourth industrial revolution and its impact on occupational health and safety, worker's compensation and labor conditions. *Safety and health at work*, 10(4), 400-408.
- [80]. Mirahadi, F., McCabe, B., & Shahi, A. (2019). IFC-centric performance-based evaluation of building evacuations using fire dynamics simulation and agent-based modeling. *Automation in Construction*, 101, 1-16.
- [81]. Morgan, A. B. (2019). The future of flame retardant polymers—unmet needs and likely new approaches. *Polymer Reviews*, 59(1), 25-54.
- [82]. Mróz, K., Hager, I., & Korniejewski, K. (2016). Material solutions for passive fire protection of buildings and structures and their performances testing. *Procedia Engineering*, 151, 284-291.
- [83]. Neitzel, D. K. (2016). Electrical hazard assessments—Do I still need to do them? 2016 IEEE/IAS 52nd Industrial and Commercial Power Systems Technical Conference (I&CPS),
- [84]. Neri, F., Laschi, A., Foderi, C., Fabiano, F., Bertuzzi, L., & Marchi, E. (2018). Determining noise and vibration exposure in conifer cross-cutting operations by using Li-Ion batteries and electric chainsaws. *Forests*, 9(8), 501.
- [85]. Nimlyat, P. S., Audu, A. U., Ola-Adisa, E. O., & Gwatau, D. (2017). An evaluation of fire safety measures in high-rise buildings in Nigeria. *Sustainable cities and society*, 35, 774-785.
- [86]. O'Donovan, P., Leahy, K., Bruton, K., & O'Sullivan, D. T. (2015). An industrial big data pipeline for data-driven analytics maintenance applications in large-scale smart manufacturing facilities. *Journal of big data*, 2(1), 25.
- [87]. Östman, B., Brandon, D., & Frantzich, H. (2017). Fire safety engineering in timber buildings. *Fire safety journal*, 91, 11-20.
- [88]. Ozdemir, Y., Gul, M., & Celik, E. (2017). Assessment of occupational hazards and associated risks in fuzzy environment: a case study of a university chemical laboratory. *Human and Ecological Risk Assessment: An International Journal*, 23(4), 895-924.
- [89]. Panteli, M., Mancarella, P., Trakas, D. N., Kyriakides, E., & Hatziaargyriou, N. D. (2017). Metrics and quantification of operational and infrastructure resilience in power systems. *IEEE Transactions on Power Systems*, 32(6), 4732-4742.

- [90]. Park, H., Meacham, B. J., Dembsey, N. A., & Goulthorpe, M. (2015). Conceptual model development for holistic building fire safety performance analysis. *Fire technology*, 51(1), 173-193.
- [91]. Patriarca, R., Di Gravio, G., Cioponea, R., & Licu, A. (2019). Safety intelligence: Incremental proactive risk management for holistic aviation safety performance. *Safety science*, 118, 551-567.
- [92]. Qari, S. H., Yusuf, H. R., Groseclose, S. L., Leinhos, M. R., & Carbone, E. G. (2019). Public health emergency preparedness system evaluation criteria and performance metrics: A review of contributions of the CDC-funded preparedness and emergency response research centers. *Disaster medicine and public health preparedness*, 13(3), 626-638.
- [93]. Quintiere, J. G. (2016). *Principles of fire behavior*. CRC Press.
- [94]. Rezvanizani, S. M., Liu, Z., Chen, Y., & Lee, J. (2014). Review and recent advances in battery health monitoring and prognostics technologies for electric vehicle (EV) safety and mobility. *Journal of power sources*, 256, 110-124.
- [95]. Roberts, D. (2015). Risk management and electrical safety: Implementation of an occupational health and safety management system. *IEEE Industry Applications Magazine*, 21(3), 67-74.
- [96]. Roege, P. E., Collier, Z. A., Mancillas, J., McDonagh, J. A., & Linkov, I. (2014). Metrics for energy resilience. *Energy Policy*, 72, 249-256.
- [97]. Runefors, M., Johansson, N., & van Hees, P. (2017). The effectiveness of specific fire prevention measures for different population groups. *Fire safety journal*, 91, 1044-1050.
- [98]. Saeed, F., Paul, A., Rehman, A., Hong, W. H., & Seo, H. (2018). IoT-based intelligent modeling of smart home environment for fire prevention and safety. *Journal of Sensor and Actuator Networks*, 7(1), 11.
- [99]. Saracoglu, A., Kuzucuoglu, T., Yakupoglu, S., Kilavuz, O., Tuncay, E., Ersoy, B., & Demirhan, R. (2014). Prognostic factors in electrical burns: a review of 101 patients. *Burns*, 40(4), 702-707.
- [100]. Scolobig, A., Prior, T., Schröter, D., Jörin, J., & Patt, A. (2015). Towards people-centred approaches for effective disaster risk management: Balancing rhetoric with reality. *International journal of disaster risk reduction*, 12, 202-212.
- [101]. Sousa, V., Almeida, N. M., & Dias, L. A. (2015). Risk-based management of occupational safety and health in the construction industry-Part 2: Quantitative model. *Safety science*, 74, 184-194.
- [102]. Stemn, E., Bofinger, C., Cliff, D., & Hassall, M. E. (2019). Examining the relationship between safety culture maturity and safety performance of the mining industry. *Safety science*, 113, 345-355.
- [103]. Stumpf, K., Knuth, D., Kietzmann, D., & Schmidt, S. (2017). Adoption of fire prevention measures-Predictors in a representative German sample. *Safety science*, 94, 94-102.
- [104]. Sund, B., Svensson, M., & Andersson, H. (2017). Demographic determinants of incident experience and risk perception: Do high-risk groups accurately perceive themselves as high-risk? *Journal of risk research*, 20(1), 99-117.
- [105]. Taylor, J. Z., & Rostron, K. I. (2018). The development of a safety and quality culture assessment tool from a longitudinal, mixed-method research journey. *Worldwide Hospitality and Tourism Themes*, 10(3), 313-329.
- [106]. Tong, L., & Dou, Y. (2014). Simulation study of coal mine safety investment based on system dynamics. *International Journal of Mining Science and Technology*, 24(2), 201-205.
- [107]. Twigg, J., Christie, N., Haworth, J., Osuteye, E., & Skarlatidou, A. (2017). Improved methods for fire risk assessment in low-income and informal settlements. *International journal of environmental research and public health*, 14(2), 139.
- [108]. Uğurlu, Ö. (2016). Analysis of fire and explosion accidents occurring in tankers transporting hazardous cargoes. *International Journal of Industrial Ergonomics*, 55, 1-11.
- [109]. Varshney, K. R. (2016). Engineering safety in machine learning. 2016 Information Theory and Applications Workshop (ITA),
- [110]. Wachter, J. K., & Yorio, P. L. (2014). A system of safety management practices and worker engagement for reducing and preventing accidents: An empirical and theoretical investigation. *Accident Analysis & Prevention*, 68, 117-130.
- [111]. Waldmann, V., Narayanan, K., Combes, N., Jost, D., Jouven, X., & Marijon, E. (2018). Electrical cardiac injuries: current concepts and management. *European heart journal*, 39(16), 1459-1465.
- [112]. Wang, B., Dehghanian, P., Wang, S., & Mitolo, M. (2019). Electrical safety considerations in large-scale electric vehicle charging stations. *IEEE Transactions on Industry Applications*, 55(6), 6603-6612.
- [113]. Wertheim-Heck, S. C., & Raneri, J. E. (2019). A cross-disciplinary mixed-method approach to understand how food retail environment transformations influence food choice and intake among the urban poor: experiences from Vietnam. *Appetite*, 142, 104370.
- [114]. Wickström, U. (2016). *Temperature calculation in fire safety engineering* (Vol. 539). Springer.
- [115]. Williams-Bell, F. M., Kapralos, B., Hogue, A., Murphy, B., & Weckman, E. (2015). Using serious games and virtual simulation for training in the fire service: a review. *Fire technology*, 51(3), 553-584.
- [116]. Wu, J., Hu, Z., Chen, J., & Li, Z. (2018). Risk assessment of underground subway stations to fire disasters using Bayesian network. *Sustainability*, 10(10), 3810.
- [117]. Xin, J., & Huang, C. F. (2014). Fire risk assessment of residential buildings based on fire statistics from China. *Fire technology*, 50(5), 1147-1161.
- [118]. Xiong, L., Bruck, D., & Ball, M. (2015). Comparative investigation of 'survival' and fatality factors in accidental residential fires. *Fire safety journal*, 73, 37-47.
- [119]. Yamada, T., & Akizuki, Y. (2016). Visibility and human behavior in fire smoke. In *SFPE handbook of fire protection engineering* (pp. 2181-2206). Springer.
- [120]. Yuan, C., He, Y., Feng, Y., & Wang, P. (2018). Fire hazards in heritage villages: A case study on Dangjia Village in China. *International journal of disaster risk reduction*, 28, 748-757.
- [121]. Zhao, D., McCoy, A., Kleiner, B., & Feng, Y. (2016). Integrating safety culture into OSH risk mitigation: a pilot study on the electrical safety. *Journal of Civil Engineering and Management*, 22(6), 800-807.

- [122]. Zhao, D., McCoy, A. P., Kleiner, B. M., & Smith-Jackson, T. L. (2015). Control measures of electrical hazards: An analysis of construction industry. *Safety science*, 77, 143-151.
- [123]. Zhou, J.-L., & Lei, Y. (2018). Paths between latent and active errors: Analysis of 407 railway accidents/incidents' causes in China. *Safety science*, 110, 47-58.
- [124]. Zhu, Y., Wang, D., Shao, Z., Xu, C., Zhu, X., Qi, X., & Liu, F. (2019). A statistical analysis of coalmine fires and explosions in China. *Process Safety and Environmental Protection*, 121, 357-366.
- [125]. Zou, P. X., Sunindijo, R. Y., & Dainty, A. R. (2014). A mixed methods research design for bridging the gap between research and practice in construction safety. *Safety science*, 70, 316-326.